



DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT  
 GOVERNMENT CENTER  
 14949 62nd STREET NORTH P.O. BOX 6 STILLWATER, MN 55082-0006  
 Office: 651-430-6655 TTY: 651-430-6246 FAX: 651-430-6730

**Subsurface Sewage Treatment System Maintenance Permit**

This section must be completed in its entirety to constitute a valid maintenance permit. This permit must be completed prior to performing maintenance activities and remain on-site for the duration of the maintenance activity.

Date of Maintenance: 8-4-17 Reason for Maintenance: Routine  
 Property Address: 19687 Manning Tr N Property Owner's Name: Ronald Ruiz  
 Municipality: Marne St Croix ZIP: \_\_\_\_\_ Property Identification Number: N/A  
 Maintenance Permit No: 1259a 7713 Maintainer Name and License No. Ross' Sewer L3448

Maintenance Performed	Tank Measurement (must be completed if tanks NOT pumped)
<input checked="" type="checkbox"/> Tank(s) Pumped <input type="checkbox"/> Sludge and scum measured Do tanks need to be pumped? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No (if no provide measurements)	<del>           Liquid Level of Tank _____ in            Sludge Level in Tank _____ in Scum Level in Tank _____ in            Sludge + Scum _____ / Liquid Level _____ X 100            = % Sludge &amp; Scum _____ Tanks must be pumped if 25% or greater         </del>

- Access used to remove septage:  Maintenance Hole  Other (enter authorization code) \_\_\_\_\_
- Were all covers securely replaced?  Yes  No
- Is there evidence of tank leakage from a septic, holding, pretreatment or pump tank below the operating depth or evidence of damaged, cracked, or structurally unsound maintenance hole covers?

Tank	Leaking Out	Leaking In	Cover Damage
Septic/Holding Tank #1	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
<del>Septic/Holding Tank #2</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>
<del>Pretreatment Tank</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>
<del>Pump Tank</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>

4. How many gallons of septage were removed?  
 Tank #1 1,500 gal Tank #2 N/A gal Pretreatment tank N/A gal Pump Tank N/A gal

5. Other information: List any troubleshooting, minor repairs conducted, tank safety concerns, or other concerns.  
Everything looks good.

6. Location of septage disposal: 2905a Dimaggio St NE North Branch, MN

Maintenance activities must be reported to the Department within 90 days.