



Department of Public Health and Environment

Lowell Johnson  
Director

Dave Brummel  
Deputy Director

3/4/2016

Lee & Barbara Booth  
16080 Scandia Trail N  
New Scandia Township MN, 55073

**1303220410003**

**NOTICE AND ORDER TO COMPLY**

On 2/18/2016 the Department received a Compliance Inspection Form for the subsurface sewage treatment system (SSTS) located at 16080 Scandia Trail N in New Scandia Township, Minnesota, GEO Code 1303220410003. The compliance inspection was conducted by Brian Humpal of Inspect Minnesota, Midwest Soil Testing on 2/18/2016.

The Compliance Inspection Report by Inspect Minnesota, Midwest Soil Testing indicates that the SSTS located at 16080 Scandia Trail N is a failing system due to the lack of the required vertical separation between the bottom system bottom and limiting soil conditions. The Compliance Inspection Report also indicates that the system is NOT an imminent threat to public health and safety.

Section 4.3, Subp. (8) of the Washington County Development Code, Chapter Four, Subsurface Sewage Treatment System Regulations (Washington County Ordinance No. 196) states:

*Any existing system which is found to be failing to protect groundwater shall be replaced or otherwise brought into compliance within six (6) months of notice and order to comply by the Department.*

Therefore, the SSTS located at 16080 Scandia Trail N that Brian Humpal deemed failing must be replaced within six (6) months of receipt of this notice. Financial assistance may be available through Washington County in the form of low interest loans which are added to the property tax statement. Grants may also be available to qualified low income residents

If you have any questions or comments, please contact me at 651-430-4052.

Sincerely,

Christopher W. LeClair, REHS  
Senior Environmental Specialist