

# WASHINGTON COUNTY, MINNESOTA

Sewage Treatment Permit No. 2983

Inspection of Installation Must Be Made By the Building Official Before Any Portion of System Is Covered  
Contact Planning Department, 439-3220 x-176, 24 HOUR NOTICE REQUIRED

Owner PATRICK RYAN

Property Description \_\_\_\_\_

Property Address 10339 JOLIET AVE NW GRANVILLE

Use of Building: HOME Flow Rate: 4 BEDROOM Percolation Rate: 7 mpi

Septic Tank 1200 Gal. Liquid Capacity Lift Station (if needed) \_\_\_\_\_ Gal.

Type of System: SEPTIC TANK DRAINFIELD

Absorption Trench — Square Feet 750 Lineal Feet 250 Width 36"

Depth of Rock Below Lines 12 Inches, Above Lines 2 Inches

Depth of Trench From Existing Grade — Minimum 24 Inches, Maximum 42 Inches

Recommended Number of Lines 3 AT X3' (Note: Maximum Length of Individual Line Is 100 Feet.)

Minimum Spacing of Lines 7 1/2 Ft. Center to Center

Special Conditions SYSTEM MUST BE IN AREA TESTED AND APPROVED. IF INTENDING TO USE EXISTING TANK IT MUST BE PUMPED & OPEN FOR INSPECTION.

PERMIT: Permission is hereby granted to the above named applicant to perform the work described in the application to the minimum specifications shown above and per attached site plan. This permit is granted upon express condition that the person to whom it is granted, and his agents, employees and workmen shall conform in all respects to ordinances of Washington County, Minnesota. This permit may be revoked at any time upon violation of any said ordinance, and permit shall be void if work is not commenced within six (6) months.

**INSTALLER MUST HOLD CURRENT SEPTIC INSTALLER LICENSE WITH WASHINGTON COUNTY.**

Approved: [Signature] Date 4-1-83  
Planning Administrator/Authorized Agent

Comments as built to be sent in to office

Installation Approved [Signature] Date 5-6-83