

OFFICE OF THE ZONING ADMINISTRATOR
WASHINGTON COUNTY, MINNESOTA
Tel. 439-3220

PERMIT TO INSTALL SEWAGE DISPOSAL SYSTEM

Owner Peter F. Riens NAME Permit No. 1256

11080 Norvall Ave N ADDRESS Stillwater Twp

MINIMUM SYSTEM REQUIRED: 5 Bedrooms, Percolation Rate 10 M in/Inch

Septic Tank 1500 Gal. Liquid Capacity Lift Station 1000 Gal.

Distribution Box _____ Drop Box _____

Absorption Trench - Square Feet 725 Lineal Feet 413 Width 24"

Depth of Rock Below Tile Lines 12 Inches, Above Tile 2 Inches

Depth of Trench - Minimum Cover 3 Inches, Maximum Cover 24 Inches

Minimum Number of Lines 5 Maximum Length of Individual Line 100 Ft.

Recommended Number of Lines 6 to 70'

Minimum Spacing of Lines 6 1/2 Ft. Center to Center.

Inspection of Installation Must Be Accomplished By This Office Before Any Portion of System Is Covered.

Special Conditions LINE FROM HOUSE TO SEPTIC TANK TO BE CAST IRON.

EMITTER LINE UNDER DRIVEWAY.

SEE DETAILS ATTACHED.

NOTE: BLDG SETBACK VARIANCE TO 150' FROM SHORELINE SUBMITTED BY WASHINGTON CO. BOARD OF ADJUSTMENT AND APPEALS

System Inspected 11-1-76 DATE Borden Exen.

Installation Approved H. Weaver INSPECTOR

Comments pump not installed this date.
pump in - 11-4-76 etc

PERMIT: Permission is hereby granted to the above named applicant to perform the work described in the application, to the specifications shown under minimum system required. This permit is granted upon express condition that the person to whom it is granted, and his agents, employees and workmen shall conform in all respects to ordinances of Washington County, Minnesota. This permit may be revoked at any time upon violation of any said ordinance, and permit shall be void if work is not commenced within (6) months. Installer must hold current Septic Installer License with Washington County.

Approved: [Signature] (ZONING ADMINISTRATOR) Dec 30, 1976 (DATE)