#### **Inspect Minnesota & Midwest Soil Testing**

P.O. Box 10853 White Bear Lake, MN 55110 651-492-7550/Brian@Midwestsoiltesting.com

Brian Humpal

MPCA Licensed Advanced Inspector

#### SUBSURFACE SEWAGE TREATMENT SYSTEM (SSTS) COMPLIANCE REPORT

**Inspection Address:** 8155 59<sup>th</sup> Street N, Lake Elmo, MN 55042

#### **REPORT SUMMARY**

I have performed an "MPCA Compliance Inspection" on this system and have reviewed a previous compliance inspection from 2012 and 2017, which were on file at Washington County. This very old system (installed in 1983) consists of a pre-cast septic tank and a rock trench drainfield.

Predicated on my inspection of the system and my review of the records, it is my opinion that this system <u>presently meets</u> MPCA minimum compliance inspection requirements.

Inspect Minnesota and Midwest Soil Testing have been hired to perform a compliance inspection of this SSTS for compliance with local ordinances pursuant to Minn. Stat. § 115.55 (2013). This compliance inspection covers only the criteria required by Minn. Stat. § 115.55 Subd. 5a (2013) and Minn. R. 7080.1500 (2011). A compliance inspection is an indication of the current compliance status of the system and does not guarantee the performance or longevity of this system beyond the date of inspection, as it is impossible to determine the future performance of any system. Inspect Minnesota and Midwest Soil Testing disclaim any use of this compliance inspection beyond determining SSTS compliance pursuant to Minn. Stat. § 115.55 Subd. 5a (2013) and Minn. R. 7080.1500 (2011).

Please contact me should you have any questions.

Brian Humpal Brian Humpal



## **Compliance Inspection Form**

## Existing Subsurface Sewage Treatment Systems (SSTS)

Doc Type: Compliance and Enforcement

Instructions: Inspection results based on Minne requirements and attached forms – additional loc	cal requirements may also apply.	For local tracking purposes:			
Submit completed form to Local Unit of Gov within 15 days	ernment (LUG) and system owner				
System Status					
System status on date (mm/dd/yyyy):	10/12/2017				
Compliant – Certificate of Co (Valid for 3 years from report date, un frame outlined in Local Ordinance.)	•	npliant – Notice of Noncompliance rade Requirements on page 3)			
<ul> <li>☐ Other Compliance Conditions (Com</li> <li>☐ Tank Integrity (Compliance Compo</li> <li>☐ Other Compliance Conditions (Com</li> <li>☐ Soil Separation (Compliance Comp</li> </ul>	ck all applicable) ce Component #1) – Imminent threat to ppliance Component #3) – Imminent thr nent #2) – Failing to protect groundwat ppliance Component #3) – Failing to pro- ponent #4) – Failing to protect groundwat equirements (Compliance Component #	reat to public health and safety Fer otect groundwater ater			
		, , , , , , , , , , , , , , , , , , ,			
Property Information	Darrack ID# or Coo/Turn/Darra				
Property address: 8155 59 <sup>th</sup> St N, Lake Elmo,	Parcel ID# or Sec/Twp/Rang				
Property address. <u> </u>		or inspection: Property Transfer ohone: 612-723-6932			
or	Owners [	012-723-0932			
Owner's representative:	Represer	ntative phone:			
Local regulatory authority: Washington Coun		Regulatory authority phone: 651-430-4052			
	ank and a rock trench drainfield.				
Comments or recommendations:					
Certification					
I hereby certify that all the necessary informatio determination of future system performance has possible abuse of the system, inadequate main	s been nor can be made due to unknow				
Inspector name: Brian Humpal		ion number: <u>L5342</u>			
Business name: <u>Inspect Minnesota, Midwest</u>	•	se number: <u>L2896</u>			
Inspector signature: Brian Hump	Pho Pho	ne number: 651-492-7550			
Necessary or Locally Required Att	achments				
Soil boring logs	built drawing	local ordinance			
☑ Other information (list): Report Summa	ry, Property Information, Disclaimer, Lic	ense			

www.pca.state.mn.us • 651-296-6300 • 800-657-3864 • TTY 651-282-5332 or 800-657-3864 • Available in alternative formats wq-wwists4-31 • 1/24/12 Page 1 of 3

Property address: 8155 59th St N, Lake Elmo, MN 55042

Inspector initials/Date: \_\_10/12/2017

1.	Impact on Public Health	<ul> <li>Compliance component</li> </ul>	#1 of 5			
	Compliance criteria:		Verification method(s):			
	System discharge sewage to the ground surface.	☐ Yes ☒ No	<ul><li>☑ Searched for surface outlet</li><li>☑ Searched for seeping in yard/backup in home</li></ul>			
	System discharge sewage to drain or surface waters.	n tile ☐ Yes ☒ No	<ul> <li>☑ Excessive ponding in soil system/D-boxes</li> <li>☐ Homeowner testimony (See Comments/Explanation)</li> <li>☑ "Plack seil" shows soil dispersal system</li> </ul>			
	System cause sewage backup int dwelling or establishment.	o ☐ Yes ☒ No	<ul> <li>☐ "Black soil" above soil dispersal system</li> <li>☐ System requires "emergency" pumping</li> <li>☐ Performed dye test</li> </ul>			
	Any "yes" answer above ind an Imminent Threat to Public		☐ Unable to verify (See Comments/Explanation) ☐ Other methods not listed (See Comments/Explanation)			
	Comments/Explanation: None of the above found. A soil boring over the drainfield in	dicated no signs of ponding o	r black/grey soils.			
2.	Tank Integrity – Compliand	ce component #2 of 5				
	Compliance criteria:		Verification method(s):			
	System consists of a seepage pit, cesspool, drywell, or leaching pit.	☐ Yes ⊠ No	<ul><li>☑ Probed tank(s) bottom</li><li>☑ Examined construction records</li></ul>			
	Seepage pits meeting 7080.2550 may compliant if allowed in local ordinance		<ul><li>Examined Tank Integrity Form (Attach)</li><li>Observed liquid level below operating depth</li></ul>			
	Sewage tank(s) leak below their designed operating depth.	☐ Yes ⊠ No	<ul><li>☐ Examined empty (pumped) tanks(s)</li><li>☐ Probed outside tank(s) for "black soil"</li></ul>			
	If yes, which sewage tank(s) leaks	5:	☐ Unable to verify (See Comments/Explanation)			
	Any "yes" answer above is system is Failing to Prote		☐ Other methods not listed (See Comments/Explanation)			
	Comments/Explanation: Lowered underwater camera into	tank - baffles and tank walls (	DK.			
3.	Other Compliance Condi	i <b>tions</b> – Compliance com	ponent #3 of 5			
	a. Maintenance hole covers are da	amaged, cracked, unsecured,	or appear to structurally unsound. ☐ Yes* ☒ No ☐ Unknown			
	b. Other issues (electrical hazards, e *System is an imminent threa		ely impact public health or safety. ☐ Yes* ☒ No ☐ Unknown			
	Explain:					
	c. System is non-protective of grow *System is failing to protect g		as determined by inspector ☐ Yes* ☒ No			
	Explain:					

www.pca.state.mn.us • 651-296-6300 • 800-657-3864 • TTY 651-282-5332 or 800-657-3864 • Available in alternative formats wq-wwists4-31 • 1/24/12 Page 2 of 3

Property address: 8155 59th St N, Lake Elmo, MN 55042

Inspector initials/Date: 10/12/2017

**Soil Separation** – Compliance component #4 of 5 Date of installation: 1983 Unknown Verification method(s): Shoreland/Wellhead protection/Food Beverage ☐ Yes ☐ No Soil observation does not expire. Previous soil Lodging? observations by two independent parties are sufficient. Compliance criteria: unless site conditions have been altered or local requirements differ. For systems built prior to April 1, 1996, and ☐ Conducted soil observation(s) (Attach boring logs) not located in Shoreland or Wellhead Protection Area or not serving a food, ☐ Two previous verifications (Attach boring logs) beverage or lodging establishment: ☐ Not applicable (Holding tank(s), no drainfield) Drainfield has at least a two-foot vertical ☐ Unable to verify (See Comments/Explanation) separation distance from periodically ☐ Other (See Comments/Explanation) saturated soil or bedrock. ☐ Yes ☐ No Non-performance systems built April 1, Comments/Explanation: 1996, or later or for non-performance Reviewed previous compliance inspection from 2012. systems located in Shoreland or Wellhead Protection Areas or serving a food, Reviewed previous complaince inspection from 2017. beverage, or lodging establishment: Drainfield has a three-foot vertical separation distance from periodically saturated soil or bedrock.\* "Experimental", "Other", or "Performance" ☐ Yes ☐ No Indicate depths of elevations systems built under pre-2008 Rules; Type IV See Attached or V systems built under 2008 Rules (7080. A. Bottom of distribution media Boring Log(s) 2350 or 7080.2400 (Advanced Inspector License required) B. Periodically saturated soil/bedrock Drainfield meets the designed vertical separation distance from periodically C. System separation saturated soil or bedrock. D. Required compliance separation\* Any "no" answer above indicates the system is \*May be reduced up to 15 percent if allowed by Local Failing to Protect Groundwater. Ordinance. 5. Operating Permit and Nitrogen BMP\* – Compliance component #5 of 5 Not applicable Is the system operated under an Operating Permit? ☐ Yes ☒ No If "yes", A below is required Is the system required to employ a Nitrogen BMP? ☐ Yes ⊠ No If "yes", B below is required BMP=Best Management Practice(s) specified in the system design If the answer to both questions is "no", this section does not need to be completed. Compliance criteria a. Operating Permit number: ☐ Yes ☐ No Have the Operating Permit requirements been met? ☐ Yes ☐ No b. Is the required nitrogen BMP in place and properly functioning? Any "no" answer indicates Noncompliance.

Upgrade Requirements (Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.


www.pca.state.mn.us • 800-657-3864 wq-wwists4-31 • 1/24/12 Page 3 of 3

## Inspect Minnesota & Midwest Soil Testing Subsurface Sewage Treatment System Owner/Property Information This information will be used for the purpose of conducting an MPCA Compliance Inspection

Date of Inspection: October 12, 2017  Time: 12:30 PM						
Date of Inspection: October 12, 2017	1 IIIIC. 12.30 FW					
Property Address: 8155 59 <sup>th</sup> St N, Lake Elmo, MN	Zip: 55042					
Property Owner: Dave Erdman	Phone: 612-723-6932					
Tank(s)       Tank(s)Material       Soil Treatment System         Septic 1       □Fiberglass       □Rock trench         □Aerobic       □Plastic       □Gravelless trench         □Lift       □Metal       □Chamber trench         □Holding       □Concrete       □Seepage bed         □Other:       □Block       □Mound         □Other       □At-grade	M Other  Alternative system  Experimental system  Cesspool system  Other system					
Are the tank maintenance covers accessible? ☐ Yes ☒ No '						
performed through the maintenance holes. Maintenance hole of						
the ground surface to facilitate access and proper maintenance	of the system.					
Year house built: 1983 Year septic installed: 1983	Tank size (gals.): 1200					
	f residents in home? 2					
Number of bedrooms? 4 Are all floors drained b						
Garbage disposal? Y Whirlpool ba	ath? Y					
More than one system (laundry, etc.)? N						
Does this property have any footing drain tiles connected to the	e septic system? N					
Are any buildings on this property such as garages or out-build	lings connected to this system? N					
Are there any additional systems on this property serving other	buildings? N					
Location of septic system on lot? South Side						
	e well a deep well? Y					
Have you ever experienced any problems with the system such as: tree roots, sewage back-ups, surfacing of sewage onto the ground, septic tank overflowing, etc.; or have any repairs been made to the system? N If yes, explain:						
	oumper: Schlomka's Sewer Service					
How often pumped in previous years? Every 5						
Have you received notices from any government agency concerning this system? N						
Is your property located in a shoreland management area? N						
Do you have any additional information that should be given to the new owner? N						
I hereby certify that the above information is correct to the best of my knowledge. I also understand that if the system is considered "non-compliant/failing" per MPCA rules, that the inspector must by law submit a copy of this report to the local government unit within 15 days of the date of inspection completion. I also agree that unless otherwise noted in						

this report, that I/we are ultimately responsible for payment of all fees for all work performed relative to this inspection

by Inspect Minnesota and Midwest Soil Testing.	•	•
Owner/Occupant:	Date:	



#### **Log Of Soil Borings**

Location of Project: 8155 59th St N, Lake Elmo, MN 55042					
Borings Made By: Inspect Minnesota				Date:	7/11/17
Auger Used: Hand/Bucket		Classification System: USDA			
Boring Number: 1		Boring Number:			
Surface Elevation of Boring  Same ground surface drainfield trench			Surface Elevation of Boring	of	
Depth In Inches	Soils E	<u>ncountered</u>	Depth In Inches	Soils Er	ncountered
0-9 9-32 32-47 47-61 61-67	10YR 3/3 10YR 4/3 Mediu Trace Of La 10YR 5/3 Trace Of La 10YR 4/4 Loa	L Loamy Sand B Loamy Sand Im To Fine Sand With Imaliae Banding Fine Sand With Imaliae Banding Imaliae Band With Imaliae Sand With Imaliae			
61"	Depth To End Of B	oring Or Redox	I	Depth To End Of Bo	oring Or Redox
Same	Elevation Of Boring	g Relative To System		Elevation Of Boring	Relative To System
-29" Depth To Bottom Of Distribution Media		Depth To Bottom Of Distribution Media			
=32"	Of Separation			Of Separation	
	End Of Boring At:	67"		End Of Boring At:	
	Redox Present At:	61"		Redox Present At:	
Standing Water Present At: None		Standing Water Present At:			

Bottom Of Distribution Medium At: 29 Inches

#### **Log Of Soil Borings**

Location of Project: 8155 59th Street N, Lake Elmo, MN 55042						
Borings Made By: Inspect Minnesota					Date:	4/17/12
Auger Used: Hand/Bucket		Class	sific	ation System:	USDA	
Boring Number: 1			Вс	oring Number:	2	
Surface Same ground surface as drainfield Elevation of at southwest end of west drainfield Boring trench		Boring distribution box inspection				
Depth In Inches	Soils E	ncountered	Depth In Inches		Soils Encountered	
0-12 12-28 28-80	7.5YR 3 7.5YR 4/4	Loamy Fine Sand /4 Fine Sand Fine Sand With ae Bands After 72"	0-10 10-33 33-70 70-78	7.5YR 2.5/3 Loamy Fine Sand 7.5YR Fine Sand With Trace Fines 7.5YR 5/4 Fine Sand With 7.5YR 3/4 & 7.5YR 4/4 Lamellae Ba		d With Trace Fines Fine Sand With R 4/4 Lamellae Bands ne Sandy Loam With
80" [	Depth To End Of B	oring Or Redox	70"	De	pth To End Of Bo	oring Or Redox
Same E	Elevation Of Boring	g Relative To System	Same	Ele	vation Of Boring	Relative To System
-28" Depth To Bottom Of System		Of System	-34" Depth To Bottom Of System			of System
	Of Separation		=36"		Separation	
ļ	Cm d Of Davis - At	00"		Г	of Davidson At 1	70"
	End Of Boring At:	80"			d Of Boring At:	78"
	Redox Present At: None			Redox Present At: 70"		
Standing Water Present At: None Standing Water Present At: None						

Bottom Of Distribution Medium At: 28 Inches At Probe 1
Bottom Of Distribution Medium At: 34 Inches At Distribution Box

#### **DISCLAIMER**

## Brian L. Humpal, Inc. dba. Inspect Minnesota, Midwest Soil Testing Relative to Subsurface Sewage Treatment System (SSTS) Compliance Inspections

- 1. This inspection/report is being performed for only the seller/owner of the property on which the SSTS is located. In such case that another party is paying for the inspection, the contract is between only said party and Brian L. Humpal, Inc.; there is no contract between Brian L. Humpal, Inc. and any other party unless otherwise noted.
- 3. Brian L. Humpal, Inc. has not been retained to warranty, guarantee, or certify the proper functioning of the SSTS for any period of time beyond the date of inspection or into the future. Because of the numerous factors (usage, maintenance, soil characteristics, previous failures, etc.) which may affect the proper operation of an SSTS, as well as the inability of Brian L. Humpal, Inc. to supervise or monitor the use or maintenance of the SSTS, the report shall not be construed as a warranty by Brian L. Humpal, Inc. that the SSTS will function properly for any particular party for any period of time.
- 4. Brian L. Humpal, Inc. is unable to verify the frequency and/or, quality of prior or future maintenance of the SSTS. Maintenance of the tank(s) must be performed through the tanks maintenance hole. The removal of solids from any location other than the maintenance hole is not a compliant method of maintenance. It is strongly recommended that maintenance covers be made accessible to the ground surface to facilitate proper maintenance.
- 5. Minimum Compliance Inspection requirements relative to this inspection and this report include <u>only</u> verification that the SSTS has tank(s) (septic tanks, lift tanks, dosing tanks, stilling tanks, etc.) which are watertight below the designed operating depth, the required separation between the bottom of the subsurface soil distribution medium and seasonally saturated soils, no back-ups of sewage into the dwelling, no discharge of sewage/effluent to the ground surface or surface waters, and no imminent safety hazards. Brian L. Humpal, Inc. does not inspect plumbing or pumps prior to the first SSTS component as these are plumbing components. The performance of exterior pumps and associated components are not inspected as they are considered to be maintenance items. Additionally, no indications relative to compliance with electrical code requirements have been made. It is recommended that any other applicable plumbing, electrical, housing, etc. inspections be performed by a qualified inspection business. Sewage back-up verification is limited to observing the floor drain area and/or the information supplied by the last occupants of the building prior to inspection. Brian L. Humpal, Inc. cannot guarantee that the information given to them by the last occupants of the building prior to inspection relative to back-ups is accurate.
- 4. Certification of this SSTS does not warranty future use beyond the date of the inspection. Any SSTS, old or new, can become hydraulically overloaded or discharge sewage/effluent to the ground surface as a result of more people moving into the house than were previously occupying the house, improper maintenance, heavy usage, leaking plumbing fixtures, groundwater infiltration, tree roots, freezing conditions, surface drainage problems, poor initial design, poor construction practices, or unsuitable materials used in constructing the system; the system can also simply stop working because of its age. An SSTS that has been properly designed and installed, properly maintained, and used in the manner for which the system was designed can be expected to provide service for twenty to twenty-five years on average. Some parts of the SSTS such as alarms, switches, pumps, filters, etc. will most likely have to be repaired or replaced over the lifetime of the system.
- 5. A Compliance Inspection is not meant to be a test or inspection for longevity of the system; a Compliance Inspection is strictly for the purpose of determining if the SSTS is protective of public health and safety, as well as the groundwater at the date and time the inspection was performed. This inspection is not intended to determine if the SSTS was originally designed or installed to past or present MPCA or other Local Government Unit code requirements. This inspection is not intended to determine if the SSTS was designed and/or installed to support the anticipated flow from the building as the use of the building may have changed since the design and construction of the SSTS due to the addition of bedrooms, occupants, etc. In addition, this inspection is not intended to determine the quality of the original SSTS design, the quality of the construction practices used while installing the SSTS, or the quality of the materials used in constructing the SSTS.
- 6. Brian L. Humpal, Inc. cannot guarantee the performance of SSTS products/components such as: gravelless pipe, chamber trenches, effluent filters, tanks, sewage pre-treatment components, piping, etc. Products such as gravelless pipe are no longer approved for installation in the State of Minnesota and may have a significantly reduced performance and/or life expectancy.
- 7. WINTER WORK: By accepting this report, it is understood that inspections conducted during winter months (approximately November 1<sup>st</sup> through April 1<sup>st</sup>) are more difficult to perform because of possible snow cover and/or ground frost. SSTS components such as tanks, maintenance covers, tank inspection pipes, subsurface distribution medium inspection pipes, and soil treatment areas are more difficult or impossible to locate due to snow cover and/or ground frost. In addition, soil borings are more difficult to perform due to snow cover and/or ground frost. Brian L. Humpal, Inc. will attempt to use the same level of standards when performing work during winter periods as when performing work during non-winter periods. However, the recipient of this report understands that because of the aforementioned considerations, the same level of standards may not be possible.
- 8. By accepting this report, the client understands that Brian L. Humpal, Inc. will not be responsible for any monetary damages exceeding the fee for the services provided.

## Subsurface Sewage Treatment Systems

Non-transferable

# Business License

## Inspect Minnesota, Midwest Soil Testing

License # L2896

License Expires: 12/22/2017

Issued: 11/29/2016

## Specialty Area(s):

Installer
Maintainer
Service Provider
Advanced Designer
Advanced Inspector

### Designated Certified Individual(s):

Cert #

Name

**Certification Expires:** 

C5342

**Brian L Humpal** 

10/15/2017

Installer, Maintainer, Serv Prov, Adv Designer, Adv Inspector

C9852

Christopher R Uebe

3/4/2018

Designer, Inspector



St. Paul, Minnesota 55155-4194

Steven Giddings, Manager

Prevention and Solid Waste Management Section