



WASHINGTON COUNTY, MINNESOTA

Department of Health, Environment,
and Land Management 612/430-6708

AFTON CITY

PERMIT NUMBER 0196012 SEWAGE PERMIT

Owner : SANDRA L COFFIN
6673 FALSTAFF RD
WOODBURY MN 55125
Applicant : SANDRA L COFFIN 612-731-4002

SEPTIC APPLICATION	100.00
SEPTIC SYSTEM PERMIT	100.00
Total Fees :	200.00
Total Paid :	100.00
Total Due :	100.00

01-96012

PERMISSION IS HEREBY GRANTED

To execute the work specified in this permit on the following described property upon express condition that said persons and their agents, employees and workmen shall conform in all respects to the provisions of the Building Code, and/or Ordinances. This permit may be revoked at any time upon the violation of any of the provisions of said code and ordinances.

Project Address : 14501 41ST ST S AFTON MN 55001

Flow Capacity 600 Gal/Day
Soil Conditions: Depth to Restriction 54 Inches Perc Rate 37 Min/Inch

Soil Treatment Area Type:
In Ground Y In Fill N Bed N Drain Field Y

- Authorized Work / Special Conditions
- Install individual sewage treatment system as per approved design in area tested and shown on site plan.
 - THIS SYSTEM MUST BE INSTALLED BY A CERTIFIED/LICENSED SEWAGE TREATMENT SYSTEM INSTALLER HOLDING A CURRENT LICENSE WITH WASHINGTON COUNTY. (A list of licensed installers is available at your request.)
 - Maximum trench depth 18", follow contours.

** Permit Expiration Date : Sewage Treatment : 5/14/97

A CERTIFICATE OF OCCUPANCY MUST BE REQUESTED AND ISSUED PRIOR TO USE OR OCCUPANCY OF WORK PERMITTED BY A BUILDING PERMIT.

** This permit shall expire and be null and void if the work authorized by the Building Permit is not commenced within 60 days of the date of issuance or if work is abandoned or suspended for a period of 120 days. Term of the Building Permit is 12 months from date of issue. Term of sewage treatment permit is 6 months from date of issue.

Penalty for violation of any of the provisions of building code: Fine not to exceed five hundred dollars (\$500.00) or imprisonment for not more than ninety (90) days, or both.

Permit Issue Date 5/14/96 Code Enforcement Officer P. Gmel