



DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT  
GOVERNMENT CENTER  
14949 62nd STREET NORTH P.O. BOX 6 STILLWATER, MN 55082-0006  
Office: 651-430-6655 TDD: 651-430-6246 FAX: 651-430-6730

### SSTS MAINTENANCE REPORT

System Location	
Address <u>12161 120TH ST. SOUTH</u>	Telephone Number
City <u>HASTINGS</u>	State <u>MN</u> ZIP <u>55033</u> Property ID No./GEO Code <u>06.026.20.22.0007</u>
Owner <u>HASTUNG ENT</u>	Pumping Date <u>9.14.2017</u>
Contractor	
Maintainer <u>Schlomka's</u>	MPCA License No. <u>3302</u> Telephone Number <u>651-437-7284</u>

**What was done to the system?**

Tank(s) Pumped

Sludge and scum measured.

Do tanks need to be pumped?

Yes  No (if no provide measurements below)

**Report Liquid Capacity in Gallons**

Tank 1: 1000  Pumped Tank 2:       Pumped

Tank 3:       Pumped Tank 4:       Pumped

Total Gallons Pumped: 1000

Visual inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

good condition

**\*Tank Measurements Use Only If Tank(s) Were NOT Pumped**

Tank Length      in.  Tank Width      in.  Tank Depth      in. = Tank Volume (cubic inches)     

Tank Radius      in.  Tank Radius      in.  3.14 = Tank Volume (cubic inches)     

Tank Volume (cu. in.)      / 231.01 = Liquid Capacity      Gallons / Tank Depth      in. = Gallons/Inch     

Sludge Level      in.  Gallons Per Inch      = Sludge Volume      Gallons


Scum Level      in.  Gallons Per Inch      = Scum Volume      Gallons

Sludge Volume      + Scum Volume      = Total Sludge and Scum Volume      Gallons

Total Sludge and Scum Volume      / Liquid Capacity      = Percent Sludge and Scum in Tank      %

\*Tanks must be pumped if either of the following conditions exist:

1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.



Tank Depth measured from invert of outlet pipe to bottom of tank

Signature [Handwritten Signature]

Date 11-01-2017

