



DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT
GOVERNMENT CENTER
14949 62nd STREET NORTH P.O. BOX 6 STILLWATER, MN 55082-0006
Office: 651-430-6655 TDD: 651-430-6246 FAX: 651-430-6730

SSTS MAINTENANCE REPORT

System Location	
Address <u>12205 131ST ST CLK S.</u>	Telephone Number
City <u>HASTINGS</u>	State <u>MN</u> ZIP <u>55033</u> Property ID No./GEO Code <u>07.026.20</u> <u>21.0004</u>
Owner <u>DANIEL MIREAU</u>	Pumping Date <u>08.08.2017</u>
Contractor	
Maintainer <u>SCHLOMKA'S</u>	MPCA License No. <u>3302</u> Telephone Number <u>651.437.7284</u>

What was done to the system?

Tank(s) Pumped

Sludge and scum measured.

Do tanks need to be pumped?

Yes No (If no provide measurements below)

Report Liquid Capacity in Gallons

Tank 1: 1000 Pumped Tank 2: Pumped

Tank 3: Pumped Tank 4: Pumped

Total Gallons Pumped: 1000

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

good condition

***Tank Measurements-Use Only if Tank(s) Were NOT Pumped**

Tank Length in. Tank Width in. Tank Depth in. = Tank Volume (cubic inches)

Tank Radius in. Tank Radius in. 3.14 = Tank Volume (cubic inches)

Tank Volume (cu. in.) / 231.01 = Liquid Capacity Gallons / Tank Depth in. = Gallons/Anch

Sludge Level in. Gallons Per Inch = Sludge Volume Gallons

Scum Level in. Gallons Per Inch = Scum Volume Gallons

Sludge Volume + Scum Volume = Total Sludge and Scum Volume Gallons

Total Sludge and Scum Volume / Liquid Capacity = Percent Sludge and Scum in Tank %

Scum Layer

Effluent

Sludge Layer

Tank Depth measured from invert of outlet pipe to bottom of tank

*Tanks must be pumped if either of the following conditions exist:

1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Signature [Handwritten Signature]

Date 11.01.2017