



### Subsurface Sewage Treatment System Maintenance Permit

This section must be completed in its entirety to constitute a valid maintenance permit. This permit must be completed prior to performing maintenance activities and remain on-site for the duration of the maintenance activity.

Date of Maintenance: 5-9-18 Reason for Maintenance: Inspection  
 Property Address: 10665 213<sup>th</sup> St North Property Owner's Name: Pat Rogowski  
 Municipality: Scandia ZIP: 55073 Property Identification Number: N/A  
 Maintenance Permit No: 6713209417 Maintainer Name and License No. Ross; Sewer Service./L3448

Maintenance Performed	Tank Measurement (must be completed if tanks NOT pumped)
<input checked="" type="checkbox"/> Tank(s) Pumped <input type="checkbox"/> Sludge and scum measured Do tanks need to be pumped? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No (if no provide measurements)	<del>           Liquid Level of Tank _____ in            Sludge Level in Tank _____ in Scum Level in Tank _____ in            Sludge + Scum _____ / Liquid Level _____ X 100            = % Sludge &amp; Scum _____ Tanks must be pumped if 25% or greater         </del>

1. Access used to remove septage:  Maintenance Hole  Other (enter authorization code)
2. Were all covers securely replaced?  Yes  No
3. Is there evidence of tank leakage from a septic, holding, pretreatment or pump tank below the operating depth or evidence of damaged, cracked, or structurally unsound maintenance hole covers? NO

Tank	Leaking Out	Leaking In	Cover Damage
Septic/Holding Tank #1	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
<del>Septic/Holding Tank #2</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>
<del>Pretreatment Tank</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>
<del>Pump Tank</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>	<del><input type="checkbox"/> Yes <input type="checkbox"/> No</del>

4. How many gallons of septage were removed?  
 Tank #1 1500 gal Tank #2 N/A gal Pretreatment tank N/A gal Pump Tank N/A gal
5. Other information: List any troubleshooting, minor repairs conducted, tank safety concerns, or other concerns.  
none

6. Location of septage disposal: 29052 Dimaggio St NE North Branch, MN

Ross' Sewer Service, inc  
 9288 County Rd 5 NE  
 North Branch, MN 55056  
 License# 3448 P: 651-674-4349