Inspect Minnesota & Midwest Soil Testing

P.O. Box 10853 White Bear Lake, MN 55110 651-492-7550/Brian@Midwestsoiltesting.com

Brian Humpal

MPCA Licensed Advanced Inspector

SUBSURFACE SEWAGE TREATMENT SYSTEM (SSTS) COMPLIANCE REPORT

Date: June 12, 2018 **Time:** 1:00 PM **Owner:** Dennis Abbott

Inspection Address: 5193 Jamaca Blvd N, Lake Elmo, MN 55042

REPORT SUMMARY

I have performed an "MPCA Compliance Inspection" on this system, have reviewed the history of the system with the owner, Dennis Abbott, and have reviewed the original design/permit records on file at the City of Lake Elmo. This system consists of two pre-cast septic tanks and a rock trench drainfield.

Predicated on my inspection of the system, my review of the history of the system with the owner, and my review of the original design/permit records, it is my opinion that this system presently meets MPCA minimum compliance inspection requirements.

Inspect Minnesota and Midwest Soil Testing have been hired to perform a compliance inspection of this SSTS for compliance with local ordinances pursuant to Minn. Stat. § 115.55 (2013). This compliance inspection covers only the criteria required by Minn. Stat. § 115.55 Subd. 5a (2013) and Minn. R. 7080.1500 (2011). A compliance inspection is an indication of the current compliance status of the system and does not guarantee the performance or longevity of this system beyond the date of inspection, as it is impossible to determine the future performance of any system. Inspect Minnesota and Midwest Soil Testing disclaim any use of this compliance inspection beyond determining SSTS compliance pursuant to Minn. Stat. § 115.55 Subd. 5a (2013) and Minn. R. 7080.1500 (2011).

Please contact me should you have any questions.

Brian Humpal Brian Humpal



Compliance Inspection Form

Existing Subsurface Sewage Treatment Systems (SSTS)

Doc Type: Compliance and Enforcement

Instructions: Inspection results based on Minnesota Pollution Control Agency (MPCA) requirements and attached forms – additional local requirements may also apply.	For local tracking purposes:	
Submit completed form to Local Unit of Government (LUG) and system owner within 15 days		
System Status		
System status on date (mm/dd/yyyy):6/12/2018		
	npliant – Notice of Noncompliance rade Requirements on page 3)	
Reason(s) for noncompliance (check all applicable) Impact on Public Health (Compliance Component #1) – Imminent threat to Other Compliance Conditions (Compliance Component #3) – Imminent threat to Tank Integrity (Compliance Component #2) – Failing to protect groundwate Other Compliance Conditions (Compliance Component #3) – Failing to protect groundwate Soil Separation (Compliance Component #4) – Failing to protect groundwate Operating permit/monitoring plan requirements (Compliance Component #4)	eat to public health and safety er tect groundwater ater	
	_	
Property Information Parcel ID# or Sec/Twp/Range	qe:	
	or inspection: Property Transfer	
• •	phone: _651-748-3622	
Owner's representative: Represen	tative phone:	
	latory authority phone: 651-430-6655	
Brief system description:		
Certification		
I hereby certify that all the necessary information has been gathered to determine the determination of future system performance has been nor can be made due to unknow possible abuse of the system, inadequate maintenance, or future water usage.		
Inspector name: Brian Humpal Certification	on number: L5342	
	se number: L2896	
Inspector signature: Brian Humpal Pho	ne number: 651-492-7550	
Necessary or Locally Required Attachments		
	local ordinance	
☑ Other information (list): Report Summary, Property Information, Disclaimer, Lic	ense	

www.pca.state.mn.us • 651-296-6300 • 800-657-3864 • TTY 651-282-5332 or 800-657-3864 • Available in alternative formats wq-wwists4-31 • 1/24/12 Page 1 of 3

Property address: _5193 Jamaca Blvd N, Lake Elmo, MN 55042

Inspector initials/Date: 6/12/2018

<u>1.</u>	lm	Impact on Public Health — Compliance component #1 of 5				
Compliance criteria: Verification method		Verification method(s):				
		stem discharge sewage to the bund surface.	☐ Yes ⊠ No	☑ Searched for surface outlet☑ Searched for seeping in yard/backup in home		
		stem discharge sewage to drain tile surface waters.	☐ Yes ☒ No	 ☑ Excessive ponding in soil system/D-boxes ☑ Homeowner testimony (See Comments/Explanation) 		
		stem cause sewage backup into velling or establishment.	☐ Yes ☒ No	 "Black soil" above soil dispersal system System requires "emergency" pumping Performed dye test 		
		ny "yes" answer above indicates Imminent Threat to Public Heal	-	☐ Unable to verify (See Comments/Explanation) ☐ Other methods not listed (See Comments/Explanation)		
	Comments/Explanation: None of the above found.					
2.	Ta	ank Integrity — Compliance com	nponent #2 of 5			
	Co	ompliance criteria:		Verification method(s):		
		stem consists of a seepage pit,	☐ Yes ⊠ No	□ Probed tank(s) bottom		
		sspool, drywell, or leaching pit.		Examined construction records		
	col	epage pits meeting 7080.2550 may be mpliant if allowed in local ordinance.		☐ Examined Tank Integrity Form (Attach)☐ Observed liquid level below operating depth		
		wage tank(s) leak below their signed operating depth.	☐ Yes ⊠ No	☐ Examined empty (pumped) tanks(s)		
		ves, which sewage tank(s) leaks:		☐ Probed outside tank(s) for "black soil"☐ Unable to verify (See Comments/Explanation)		
Any "yes" answer above indicates the ⊠ system is Failing to Protect Groundwater.			☑ Other methods not listed (See Comments/Explanation)			
	Comments/Explanation:					
	Lo	wered underwater camera into tanks -	- baffles and tank walls OK.			
3.	Ωí	ther Compliance Conditions	S — Compliance compone	nt #3 of 5		
<u> </u>		•	·			
	a. Maintenance hole covers are damaged, cracked, unsecured, or appear to structurally unsound. Yes* No Unknow Description of the covers are damaged, cracked, unsecured, or appear to structurally unsound. Yes* No Unknow Unknow					
	*System is an imminent threat to public health and safety Explain:					
	c. System is non-protective of ground water for other conditions as determined by inspector			termined by inspector ☐ Yes* ☒ No		
		Explain:				

www.pca.state.mn.us • 651-296-6300 • 800-657-3864 • TTY 651-282-5332 or 800-657-3864 • Available in alternative formats wq-wwists4-31 • 1/24/12 Page 2 of 3

Property address: 5193 Jamaca Blvd N, Lake Elmo, MN 55042

Inspector initials/Date: 6/12/2018

	Data of installation: 2004	—			idia adam are de este o		
	Date of installation: 2001 Shoreland/Wellhead protection/Food Beverage	Unkr			ification method(s):		
	Lodging?	☐ Yes	⊠ No		observation does not expire. Fervations by two independent p		
	Compliance criteria:			unle	ss site conditions have been a		
	For systems built prior to April 1, 1996, and not located in Shoreland or Wellhead Protection Area or not serving a food, beverage or lodging establishment:	☐ Yes	□ No		uirements differ. Conducted soil observation(s) Two previous verifications (Atta Not applicable (Holding tank(s), I	nch boring logs)	
	Drainfield has at least a two-foot vertical separation distance from periodically saturated soil or bedrock.				Unable to verify (See Comments Other (See Comments/Explanatio	fy (See Comments/Explanation)	
	Non-performance systems built April 1, 1996, or later or for non-performance systems located in Shoreland or Wellhead Protection Areas or serving a food, beverage, or lodging establishment:	⊠ Yes	□ No		nments/Explanation: iewed design and permit record	ds.	
	Drainfield has a three-foot vertical separation distance from periodically saturated soil or bedrock.*						
	"Experimental", "Other", or "Performance" Systems built under pre-2008 Rules; Type IV	☐ Yes	s 🗌 No	Indi	cate depths of elevations	Coo Attoched	
	or V systems built under 2008 Rules (7080. 2350 or 7080.2400 (Advanced Inspector License required)			_A. B	ottom of distribution media	See Attached Boring Log(s)	
	Drainfield meets the designed vertical separation distance from periodically saturated soil or bedrock.				Periodically saturated soil/bedrock system separation		
				D. R	Required compliance separation*		
Any "no" answer above indicates the system is Failing to Protect Groundwater. *May be reduced up to 15 percent if allowed by Local Ordinance.					•		
· .	Operating Permit and Nitrogen B		-			DIICADIE	
	Is the system operated under an Operating Permit? Yes No If "yes", A below is required Is the system required to employ a Nitrogen BMP? Yes No If "yes", B below is required						
	BMP=Best Management Practice(s) specified in the system design						
			-	_	- d to be completed		
	If the answer to both questions is "no",	tnis sec	tion aces	not nee	ea to be completea.		
	Compliance criteria						
	Operating Permit number: Have the Operating Permit requirements been met?		☐ Yes ☐ No				
b. Is the required nitrogen BMP in place and properly functioning? ☐ Yes ☐			☐ Yes ☐ No				

Upgrade Requirements (Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.

www.pca.state.mn.us • 651-296-6300 • 800-657-3864 TTY 651-282-5332 or 800-657-3864 • Available in alternative formats wq-wwists4-31 • 1/24/12 Page 3 of 3


Inspect Minnesota & Midwest Soil Testing Subsurface Sewage Treatment System Owner/Property Information

This information will be used for the purpose of conducting an MPCA Compliance Inspection.

Date of Inspection: June 12, 2018	Time: 1:00 PM			
Property Address: 5193 Jamaca Blvd N, Lake Elmo, MN	Zip: 55042			
Property Owner: Dennis Abbott	Phone: 651-748-3622			
Tank(s) Tank(s)Material Soil Treatment System Septic 2 Fiberglass Rock trench Aerobic Plastic Gravelless trench Lift Metal Chamber trench Holding Concrete Seepage bed Other: Block Mound Other At-grade	Other Alternative system Experimental system Cesspool system Other system			
Are the tank maintenance covers accessible? ⊠ Yes ☐ No *If r performed through the maintenance holes. Maintenance hole cove the ground surface to facilitate access and proper maintenance of the	ers should be made accessible to			
1	Tank size (gals.): 2-1000			
	sidents in home? 2			
Number of bedrooms? 4 Are all floors drained by gr	2			
Garbage disposal? Y Whirlpool bath?	N			
More than one system (laundry, etc.)? N				
Does this property have any footing drain tiles connected to the sep	ptic system? N			
Are any buildings on this property such as garages or out-buildings connected to this system? N Are there any additional systems on this property serving other buildings? N				
l	8.1.1			
Location of septic system on lot? East Side				
	well a deep well? Y			
Have you ever experienced any problems with the system such as: tree roots, sewage back-ups, surfacing of sewage onto the ground, septic tank overflowing, etc.; or have any repairs been made to the system? N If yes, explain:				
When was the system last pumped? June 2018 Name of pumper: Pinky's Sewer Service				
How often pumped in previous years? Every 3 Is system on a monitoring plan? N				
Have you received notices from any government agency concerning this system? N				
Is your property located in a shoreland management area? N				
Do you have any additional information that should be given to the new owner? N				

I hereby certify that the above information is correct to the best of my knowledge. I also understand that if the system is considered "non-compliant/failing" per MPCA rules, that the inspector must by law submit a copy of this report to the local government unit within 15 days of the date of inspection completion. I also agree that unless otherwise noted in this report, that I/we are ultimately responsible for payment of all fees for all work performed relative to this inspection by Inspect Minnesota and Midwest Soil Testing.

Owner/Occupant: Dennis Abbott's Signature On File Date: 6/12/2018



Log Of Soil Borings

Location of Project: 5193 Jamaca Blvd N, Lake Elmo, MN 55042					
Borings Made By: Inspect Minnesota				Date:	6/12/18
Auger Used: Hand/Bucket			Classi	ification System:	USDA
Boring Number: 1			Boring Number:		
Surface Elevation of Boring Same ground surface of drainfield trench			Surface Elevation Boring		
Depth In Inches	Soils E	ncountered	Depth In Inches	Soils En	ncountered
0-11 11-27 27-31 31-43 43-65	10YR 3 10YR 10YR 4/4 Loam ≈20% Ro 5YR 4/4 Sandy ≈10% Ro	/2 Silt Loam /3 Silt Loam 4/4 Loam ny Sand With Gravel ock Fragments y Loam With Gravel ock Fragments sal At 65"			
65"	Depth To End Of B	oring Or Redox		Depth To End Of Bo	oring Or Redox
Same	Elevation Of Boring	g Relative To System		Elevation Of Boring	Relative To System
-33" Depth To Bottom Of Distribution Media				f Distribution Media	
≥32"	Of Separation			Of Separation	
	End Of Paring At	65"		End Of Paring At.	
	End Of Boring At:			End Of Boring At: Redox Present At:	
Redox Present At: None			Water Present At:		
Standing Water Present At: None		Standing	water Fresent At.		

Bottom Of Distribution Medium At: 33 Inches	

BOREHOLE DIAMETER 4"-3%"-2%" HAND BUGER

MEZZENGA 四年 4, JAMBER BUND 107 (A) JOB

5-7-01 DATE

CLASSIFICATION 8 of 10 100 ELLOWISH BROWN LOAM BROWN 7/7 3016 BROWN MOHT 7.57R LOPIN 7.5 YR SAND 107R MEDIUM SAND BROWN. BROWN BROWN, SANDY 2017 e= 0 # () STOP 2 YELLOWISH HOLE 707 人一のけて OKAY LOAM - LOBER 月七八八 YELLOWISH BROWN LIGHT BROWN MEDIUM SAND 70P 501L #4 STOP HOLE BAM FINE TO MEDIAM. BROWN LIGHT BROWN, OBSTRUCTION 2001 のスペン エナ £ # YELLO WISH HOLE GARDI 70P BROWN, SANDY ELLOWISH BROWN LIGHT BROWN, MEDIUM SAND 0.0 5011 HOLE #2 2 STOP LOPM 70P 日マール のスピン DEE REDDISH BROWN ELLOWISH BROWN WENT BROWN MEDIUM SAND SANDY #, 10P SOIL S70p HOLE BROWN LOAM DEPTH 10 2 S 9 4 ω 6

DISCLAIMER

Brian L. Humpal, Inc. dba. Inspect Minnesota, Midwest Soil Testing Relative to Subsurface Sewage Treatment System (SSTS) Compliance Inspections

- 1. This inspection/report is being performed for only the seller/owner of the property on which the SSTS is located. In such case that another party is paying for the inspection, the contract is between only said party and Brian L. Humpal, Inc.; there is no contract between Brian L. Humpal, Inc. and any other party unless otherwise noted.
- 3. Brian L. Humpal, Inc. has not been retained to warranty, guarantee, or certify the proper functioning of the SSTS for any period of time beyond the date of inspection or into the future. Because of the numerous factors (usage, maintenance, soil characteristics, previous failures, etc.) which may affect the proper operation of an SSTS, as well as the inability of Brian L. Humpal, Inc. to supervise or monitor the use or maintenance of the SSTS, the report shall not be construed as a warranty by Brian L. Humpal, Inc. that the SSTS will function properly for any particular party for any period of time.
- 4. Brian L. Humpal, Inc. is unable to verify the frequency and/or, quality of prior or future maintenance of the SSTS. Maintenance of the tank(s) must be performed through the tanks maintenance hole. The removal of solids from any location other than the maintenance hole is not a compliant method of maintenance. It is strongly recommended that maintenance covers be made accessible to the ground surface to facilitate proper maintenance.
- 5. Minimum Compliance Inspection requirements relative to this inspection and this report include <u>only</u> verification that the SSTS has tank(s) (septic tanks, lift tanks, dosing tanks, stilling tanks, etc.) which are watertight below the designed operating depth, the required separation between the bottom of the subsurface soil distribution medium and seasonally saturated soils, no back-ups of sewage into the dwelling, no discharge of sewage/effluent to the ground surface or surface waters, and no imminent safety hazards. Brian L. Humpal, Inc. does not inspect plumbing or pumps prior to the first SSTS component as these are plumbing components. The performance of exterior pumps and associated components are not inspected as they are considered to be maintenance items. Additionally, no indications relative to compliance with electrical code requirements have been made. It is recommended that any other applicable plumbing, electrical, housing, etc. inspections be performed by a qualified inspection business. Sewage back-up verification is limited to observing the floor drain area and/or the information supplied by the last occupants of the building prior to inspection. Brian L. Humpal, Inc. cannot guarantee that the information given to them by the last occupants of the building prior to inspection relative to back-ups is accurate.
- 4. Certification of this SSTS does not warranty future use beyond the date of the inspection. Any SSTS, old or new, can become hydraulically overloaded or discharge sewage/effluent to the ground surface as a result of more people moving into the house than were previously occupying the house, improper maintenance, heavy usage, leaking plumbing fixtures, groundwater infiltration, tree roots, freezing conditions, surface drainage problems, poor initial design, poor construction practices, or unsuitable materials used in constructing the system; the system can also simply stop working because of its age. An SSTS that has been properly designed and installed, properly maintained, and used in the manner for which the system was designed can be expected to provide service for twenty to twenty-five years on average. Some parts of the SSTS such as alarms, switches, pumps, filters, etc. will most likely have to be repaired or replaced over the lifetime of the system.
- 5. A Compliance Inspection is not meant to be a test or inspection for longevity of the system; a Compliance Inspection is strictly for the purpose of determining if the SSTS is protective of public health and safety, as well as the groundwater at the date and time the inspection was performed. This inspection is not intended to determine if the SSTS was originally designed or installed to past or present MPCA or other Local Government Unit code requirements. This inspection is not intended to determine if the SSTS was designed and/or installed to support the anticipated flow from the building as the use of the building may have changed since the design and construction of the SSTS due to the addition of bedrooms, occupants, etc. In addition, this inspection is not intended to determine the quality of the original SSTS design, the quality of the construction practices used while installing the SSTS, or the quality of the materials used in constructing the SSTS.
- 6. Brian L. Humpal, Inc. cannot guarantee the performance of SSTS products/components such as: gravelless pipe, chamber trenches, effluent filters, tanks, sewage pre-treatment components, piping, etc. Products such as gravelless pipe are no longer approved for installation in the State of Minnesota and may have a significantly reduced performance and/or life expectancy.
- 7. WINTER WORK: By accepting this report, it is understood that inspections conducted during winter months (approximately November 1st through April 1st) are more difficult to perform because of possible snow cover and/or ground frost. SSTS components such as tanks, maintenance covers, tank inspection pipes, subsurface distribution medium inspection pipes, and soil treatment areas are more difficult or impossible to locate due to snow cover and/or ground frost. In addition, soil borings are more difficult to perform due to snow cover and/or ground frost. Brian L. Humpal, Inc. will attempt to use the same level of standards when performing work during winter periods as when performing work during non-winter periods. However, the recipient of this report understands that because of the aforementioned considerations, the same level of standards may not be possible.
- 8. By accepting this report, the client understands that Brian L. Humpal, Inc. will not be responsible for any monetary damages exceeding the fee for the services provided.

Subsurface Sewage Treatment Systems Non-transferable Business License

Inspect Minnesota, Midwest Soil Testing

License # L2896

License Expires: 12/22/2018

Issued: 10/10/2017

es:

Specialty Area(s):

Installer
Maintainer
Service Provider
Advanced Designer
Advanced Inspector

Designated Certified Individual(s):

Cert #	Name	Certification Expir
C9633	Anthony P Scully	7/28/2018
	Installer, Designer (Conditional)	
C5342	Brian L Humpal	10/15/2020
	Installer, Maintainer, Serv Prov,	Adv Designer, Adv Inspector
C9852	Christopher R Uebe	3/4/2018
	Designer, Inspector	



520 Lafayette Road North St. Paul, Minnesota 55155-4194 Charles & Thompson

Charles K Thompson, Supervisor Certification & Training Unit