

## SSTS MAINTENANCE REPORT

### System Location

Address 16050 quality tr		Telephone Number	
City Scandia	State MN	ZIP 55073	Property ID No./GEO Code
Owner andrew zierman		Pumping Date Jul 13, 2018	

### Contractor

Maintainer Row Sewer Service	MPCA License No. L3309	Telephone Number (651) 465-5505
------------------------------	------------------------	---------------------------------

### What was done to the system?

Tank(s) Pumped  
 Sludge and scum measured.  
 Do tanks need to be pumped?  
 Yes  No (If no provide measurements below)

### Report Liquid Capacity in Gallons

Tank 1: 1,250	<input checked="" type="checkbox"/> Pumped	Tank 2: _____	<input type="checkbox"/> Pumped
Tank 3: _____	<input type="checkbox"/> Pumped	Tank 4: _____	<input type="checkbox"/> Pumped
Total Gallons Pumped: 1,250			

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

RECEIVED

JUL 23 2018

PUBLIC HEALTH

### \*Tank Measurements-Use Only if Tank(s) Were NOT Pumped

Tank Length \_\_\_\_\_ in.  Tank Width \_\_\_\_\_ in.  Tank Depth \_\_\_\_\_ in. = Tank Volume (cubic inches) \_\_\_\_\_

Tank Radius \_\_\_\_\_ in.  Tank Radius \_\_\_\_\_ in.  3.14 = Tank Volume (cubic inches) \_\_\_\_\_


Tank Volume (cu. in.) \_\_\_\_\_ / 231.01 = Liquid Capacity \_\_\_\_\_ Gallons / Tank Depth \_\_\_\_\_ in. = Gallons/Inch \_\_\_\_\_

Sludge Level \_\_\_\_\_ in.  Gallons Per Inch \_\_\_\_\_ = Sludge Volume \_\_\_\_\_ Gallons

Scum Level \_\_\_\_\_ in.  Gallons Per Inch \_\_\_\_\_ = Scum Volume \_\_\_\_\_ Gallons

Sludge Volume \_\_\_\_\_ + Scum Volume \_\_\_\_\_ = Total Sludge and Scum Volume \_\_\_\_\_ Gallons

Total Sludge and Scum Volume \_\_\_\_\_ / Liquid Capacity \_\_\_\_\_ = Percent Sludge and Scum in Tank \_\_\_\_\_ %



Tank Depth measured from invert of outlet pipe to bottom of tank

\*Tanks must be pumped if either of the following conditions exist:  
 1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or  
 2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Signature [Handwritten Signature]

Date 7/13/18

Reset Form