



Minnesota Pollution Control Agency

520 Lafayette Road North
St. Paul, MN 55155-4194

Compliance Inspection Form
Existing Subsurface Sewage Treatment Systems (SSTS)

Doc Type: Compliance and Enforcement

Inspection results based on Minnesota Pollution Control Agency (MPCA) requirements and attached forms - additional local requirements may also apply.

Submit completed form to Local Unit of Government (LUG) and system owner within 15 days

For local tracking purposes:

System Status

System status on date (mm/dd/yyyy): 4/20/2016

[X] Compliant - Certificate of Compliance
(Valid for 3 years from report date, unless shorter time frame outlined in Local Ordinance.)

[ ] Noncompliant - Notice of Noncompliance
(See Upgrade Requirements on page 3.)

Reason(s) for noncompliance (check all applicable)

- [ ] Impact on Public Health (Compliance Component #1) - Imminent threat to public health and safety
[ ] Other Compliance Conditions (Compliance Component #3) - Imminent threat to public health and safety
[ ] Tank Integrity (Compliance Component #2) - Failing to protect groundwater
[ ] Other Compliance Conditions (Compliance Component #3) - Failing to protect groundwater
[ ] Soil Separation (Compliance Component #4) - Failing to protect groundwater
[ ] Operating permit/monitoring plan requirements (Compliance Component #5) - Noncompliant

Property Information

Parcel ID# or Sec/Twp/Range:

Property address: 4819 235th Ave N Forest Lake MN 55025

Reason for inspection: Sale

Property owner: Ryan LaPointe

Owner's phone: 651-685-4704

or

Owner's representative:

Representative phone:

Local regulatory authority: Washington County

Regulatory authority phone: 651-430-6655

Brief system description: 1500 gallon septic tank, 1000 gallon tank with a lift, mound dispersal system

Comments or recommendations:

Certification

I hereby certify that all the necessary information has been gathered to determine the compliance status of this system. No determination of future system performance has been nor can be made due to unknown conditions during system construction, possible abuse of the system, inadequate maintenance, or future water usage.

Inspector name: Benjamin Zierke

Certification number: 9594

Business name: Zierke Soil Testing

License number: 119

Inspector signature: [Signature]

Phone number: 651-462-2294

Necessary or Locally Required Attachments

- [X] Soil boring logs [X] System/As-built drawing [ ] Forms per local ordinance
[X] Other information (list): Pumping Report

**1. Impact on Public Health – Compliance component #1 of 5**

**Compliance criteria:**

System discharges sewage to the ground surface.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
System discharges sewage to drain tile or surface waters.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
System causes sewage backup into dwelling or establishment.	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

**Any "yes" answer above indicates the system is an imminent threat to public health and safety.**

Comments/Explanation:

**Verification method(s):**

- Searched for surface outlet
- Searched for seeping in yard/backup in home
- Excessive ponding in soil system/D-boxes
- Homeowner testimony (See Comments/Explanation)
- "Black soil" above soil dispersal system
- System requires "emergency" pumping
- Performed dye test
- Unable to verify (See Comments/Explanation)
- Other methods not listed (See Comments/Explanation)

**2. Tank Integrity – Compliance component #2 of 5**

**Compliance criteria:**

System consists of a seepage pit, cesspool, drywell, or leaching pit. <i>Seepage pits meeting 7080.2550 may be compliant if allowed in local ordinance.</i>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Sewage tank(s) leak below their designed operating depth. If yes, which sewage tank(s) leaks:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

**Any "yes" answer above indicates the system is failing to protect groundwater.**

Comments/Explanation:

Tanks pumped by Olson's with no issues 4/15/2016. See attached report.

**Verification method(s):**

- Probed tank(s) bottom
- Examined construction records
- Examined Tank Integrity Form (Attach)
- Observed liquid level below operating depth
- Examined empty (pumped) tanks(s)
- Probed outside tank(s) for "black soil"
- Unable to verify (See Comments/Explanation)
- Other methods not listed (See Comments/Explanation)

**3. Other Compliance Conditions – Compliance component #3 of 5**

- a. Maintenance hole covers are damaged, cracked, unsecured, or appear to be structurally unsound.  Yes\*  No  Unknown
- b. Other issues (electrical hazards, etc.) to immediately and adversely impact public health or safety.  Yes\*  No  Unknown  
**\*System is an imminent threat to public health and safety.**

Explain:

- c. System is non-protective of ground water for other conditions as determined by inspector.  Yes\*  No  
**\*System is failing to protect groundwater.**

Explain:

**4. Soil Separation – Compliance component #4 of 5**

Date of installation: \_\_\_\_\_  Unknown  
(mm/dd/yyyy)

Shoreland/Wellhead protection/Food beverage lodging?  Yes  No

**Compliance criteria:**

For systems built prior to April 1, 1996, and not located in Shoreland or Wellhead Protection Area or not serving a food, beverage or lodging establishment:  Yes  No

Drainfield has at least a two-foot vertical separation distance from periodically saturated soil or bedrock.

Non-performance systems built April 1, 1996, or later or for non-performance systems located in Shoreland or Wellhead Protection Areas or serving a food, beverage, or lodging establishment:  Yes  No

Drainfield has a three-foot vertical separation distance from periodically saturated soil or bedrock.\*

“Experimental”, “Other”, or “Performance” systems built under pre-2008 Rules; Type IV or V systems built under 2008 Rules (7080.2350 or 7080.2400 (Advanced Inspector License required)  Yes  No

Drainfield meets the designed vertical separation distance from periodically saturated soil or bedrock.

**Any “no” answer above indicates the system is failing to protect groundwater.**

**Verification method(s):**

Soil observation does not expire. Previous soil observations by two independent parties are sufficient, unless site conditions have been altered or local requirements differ.

Conducted soil observation(s) (Attach boring logs)

Two previous verifications (Attach boring logs)

Not applicable (Holding tank(s), no drainfield)

Unable to verify (See Comments/Explanation)

Other (See Comments/Explanation)

**Comments/Explanation:**

**Indicate depths or elevations**

A. Bottom of distribution media	104.0
B. Periodically saturated soil/bedrock	100.7
C. System separation	3.3
D. Required compliance separation*	3.0

\*May be reduced up to 15 percent if allowed by Local Ordinance.

**5. Operating Permit and Nitrogen BMP\* – Compliance component #5 of 5**  **Not applicable**

Is the system operated under an Operating Permit?  Yes  No **If “yes”, A below is required**

Is the system required to employ a Nitrogen BMP?  Yes  No **If “yes”, B below is required**

BMP = Best Management Practice(s) specified in the system design

**If the answer to both questions is “no”, this section does not need to be completed.**

**Compliance criteria**

a. Operating Permit number: \_\_\_\_\_  
Have the Operating Permit requirements been met?  Yes  No

b. Is the required nitrogen BMP in place and properly functioning?  Yes  No

**Any “no” answer indicates Noncompliance.**

**Upgrade Requirements (Minn. Stat. § 115.55)** An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.

## Logs of Soil Borings

Location of Project: 4819 235th Ave N Forest Lake MN 55025

Borings Made by Ben Zierke

Date:

3/29/2015

Hand bucket auger used for borings; USDA - SCS Soil Classification used.

Depth, in Inches	Boring Number 1	Depth, in Inches	Boring Number 2
0-----	-----	0-----	-----
0-10"	10YR 3/3 loamy sand, strong redox	0-12"	Sandy fill
10-14"	10YR 5/4 loamy sand, strong redox	12-18"	10YR 3/2 loamy sand, redox present throughout profile
		18-24"	10YR 5/4 loamy sand, strong redox

End of boring at 1.2 feet  
**Standing water table:**  
 Present at \_\_\_\_\_ feet of depth \_\_\_\_\_ Hours after boring  
 Standing water not present in hole   
**Mottled Soil:**  
 Observed at 0 feet of depth \_\_\_\_\_  
 Mottled soil not present in bore hole   
 Comments:


End of boring at 2 feet  
**Standing water table:**  
 Present at \_\_\_\_\_ feet of depth \_\_\_\_\_ Hours after boring  
 Standing water not present in hole   
**Mottled Soil:**  
 Observed at 1 feet of depth \_\_\_\_\_  
 Mottled soil not present in bore hole   
 Comments:

Depth, in Inches	Boring Number 3	Depth, in Inches	Boring Number 4
0-----	-----	0-----	-----

End of boring at \_\_\_\_\_ feet  
**Standing water table:**  
 Present at \_\_\_\_\_ feet of depth \_\_\_\_\_ Hours after boring  
 Standing water not present in hole   
**Mottled Soil:**  
 Observed at \_\_\_\_\_ feet of depth \_\_\_\_\_  
 Mottled soil not present in bore hole   
 Comments:

End of boring at \_\_\_\_\_ feet  
**Standing water table:**  
 Present at \_\_\_\_\_ feet of depth \_\_\_\_\_ Hours after boring  
 Standing water not present in hole   
**Mottled Soil:**  
 Observed at \_\_\_\_\_ feet of depth \_\_\_\_\_  
 Mottled soil not present in bore hole   
 Comments:

Relative Elevations	
B1:	100.0, redox 100.0
B2:	101.7, redox 100.7
Bottom of rock: 104.0	
B1 Separation: 4.0	
B2 Separation: 3.3	
Benchmark: 102.9 (garage floor)	



1991

© 2016 Google

Imagery Date: 8/11/2015 45°17'21.80" N 93°00'30.37" W elev 921 ft eye alt 1316 ft

Google earth

# Service Order

Service Order #: 77843

Olson's Sewer Service, Inc. 17638 Lyons Street N.E. Forest Lake, MN 55025 651-464-2082

Date:  Preferred Time:  Directions:  Road Restrictions (Tons)

**Addr:** 4819 235th Street North  
**Name:** Lisa & Ryan LaPointe      C1: (651) 982-6377 Lisa's cell  
**City:** Forest Lake, MN 55025      C2: (612) 685-4704 Ryan's cell  
**Cty:** Washington  
**Twp:** Forest Lake

Tank Type	Pre-cast		<b>PreT</b>	<b>T1</b>	<b>T1C</b>	<b>T2</b>	<b>T3</b>	<b>LS</b>
Treatment Type	Mound System	Sizes:		1500				1000
Treatment Area		Depths:		4"	C			Grade
Dist to Tank 1	60 Ft	Depth to Inlet:						
Dist to Lift Tank		Depth to Outlet:						
		Liquid Depth:						

Water Meter		Power Disconnect at Lift		<b>PreT</b>	<b>T1</b>	<b>T1C</b>	<b>T2</b>	<b>T3</b>	<b>LS</b>
Effluent Filter		Looped		Covers Secure:	Y				Y
Two Techs		# Bedrooms		Infiltration:	N				N
City Sewer	N	Pump Breaker		Scum Depth:	12				6
Install Date				Sludge Depth:	6				0
Installer				Inlet Baffle Intact:	Y				Y
				Outlet Baffle Intact:	Y				
As Built	None available			Pump Function:					Y
Cleanout				Alarm Function:					Y
Lift Pump				Filter Alarm Function:					

Service Type	Last Service Date	Mobilize Time	At Site Time	Complete Time	Disposal Time	Leave Disposal Time
1 Lift Station Maintenance	9/12/2011	11:30 AM	11:35 AM	12:55 PM		
2 Maintenance Pumping	10/3/2011					
3 LUG Permit						
4 Crust Buster						

Time Dosing		Iron Filter		S&E Quality		Eq Dist Hgt 1		<b>Readings</b>	<b>Previous</b>	<b>Functioning</b>
Lint Filter		Sump Pump		PH Reading		2		Event/Cycle Ctr		
Switch Tree		Ejector Pump		Non Dom Wastes		3		Elapsed Time		
Event Counter		Mgmt Plan		TA Visual Insp		4		Time Dosing		
Garbage Disp.		Monitoring				5		Water Meter		
Water Softener		Irrigation				6				

<b>Dump Site</b>	<b>Gal Pumped</b>	CSR	Liz	Reminder	4/13/2019
Harris	1935	Garden Hose		Lift Station Last Service	9/12/2011
<b>Total:</b>	<b>1935</b>	FollowUp		Vehicle	09
		Sewage Type Disposed	<input checked="" type="checkbox"/> Septage <input type="checkbox"/> Tank <input type="checkbox"/> Commercial	Service Person	BD
		Amt Billed	537.00	Payment Type	cc on file;
				Inv #	83141

( No charge to dig out cover on tank ① - )