

SSTS MAINTENANCE REPORT

System Location		
Address <u>20550 July Ave N.</u>	Telephone Number <u>612-770-7485</u>	
City <u>Forest Lake</u>	State <u>MN</u> ZIP <u>55025</u>	Property ID No./GEO Code <u>24.032.21.24.0220</u>
Owner <u>NEIL Petrowske</u>	Pumping Date	
Contractor		
Maintainer	MPCA License No.	Telephone Number

What was done to the system?

Tank(s) Pumped

Sludge and scum measured. Do tanks need to be pumped?

Yes No *(If no provide measurements below)*

Report Liquid Capacity in Gallons

Tank 1: _____ Pumped Tank 2: _____ Pumped

Tank 3: _____ Pumped Tank 4: _____ Pumped

Total Gallons Pumped: _____

Visual Inspection (note any problems with the system):


NOTE: This does not serve as a compliance inspection.

***Tank Measurements-Use Only If Tank(s) Were NOT Pumped**

Liquid Level of Tank (Distance from invert of outlet pipe to bottom of tank: 48 in.

Sludge Level 3 in. + Scum Level 1 in. = Total Sludge and Scum Level 4 in.

Total Sludge and Scum Level 4 in. / Liquid Level 48 in. = Sludge and Scum percent in Tank 8 %



*Tanks must be pumped if either of the following conditions exist:

1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Signature

Neil Petrowske

Date:

10-17-18

2018
\$22.00 Processing Fee
 Make Checks payables and remit to:
 Washington County Public Health and Environment
 14949 62nd St N
 Stillwater, MN 55082