

SSTS MAINTENANCE REPORT

System Location

Address 14421 10th St. N. Telephone Number 651-600-9060

City Stillwater State MN ZIP 55082 Property ID No./GEO Code _____

Owner Kevin Neubauer Pumping Date 6/25/14

Contractor

Maintainer Meyer Sewer Service MPCA License No. 915 Telephone Number (651) 459-0162

What was done to the system?

Tank(s) Pumped 1

Sludge and scum measured.

Do tanks need to be pumped?

Yes No (If no provide measurements below)

Report Liquid Capacity in Gallons

Tank 1: 1500 Pumped Tank 2: _____ Pumped

Tank 3: _____ Pumped Tank 4: _____ Pumped

Total Gallons Pumped: 1500

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

***Tank Measurements-Use Only If Tank(s) Were NOT Pumped**

Tank Length _____ in. X Tank Width _____ in. X Tank Depth _____ in. = Tank Volume (cubic inches)

Tank Radius _____ in. X Tank Radius _____ in. X 3.14 = Tank Volume (cubic inches)


Tank Volume (cu. in.) _____ / 231.01 = Liquid Capacity _____ Gallons / Tank Depth _____ in. = Gallons/Inch

Sludge Level _____ in. X Gallons Per Inch _____ = Sludge Volume _____ Gallons

Scum Level _____ in. X Gallons Per Inch _____ = Scum Volume _____ Gallons

Sludge Volume _____ + Scum Volume _____ = Total Sludge and Scum Volume _____ Gallons

Total Sludge and Scum Volume _____ / Liquid Capacity _____ = Percent Sludge and Scum in Tank _____ %



*Tanks must be pumped if either of the following conditions exist:

1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Signature [Handwritten Signature]

Date 6/25/14

Reset Form