

SSTS MAINTENANCE REPORT

System Location		
Address <u>3291 Lampert Ave N</u>	Telephone Number	
City <u>Lake Elmo</u>	State <u>MN</u> ZIP <u>55042</u>	Property ID No./GEO Code
Owner <u>Justin Smith</u>	Pumping Date <u>10/15/15</u>	
Contractor		
Maintainer <u>MEYER SEWER</u>	MPCA License No. <u>915</u>	Telephone Number <u>651-459-016</u>

What was done to the system?
<input checked="" type="checkbox"/> Tank(s) Pumped <input type="checkbox"/> Sludge and scum measured. Do tanks need to be pumped? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements below)


Report Liquid Capacity in Gallons
Tank 1: <u>1200</u> <input checked="" type="checkbox"/> Pumped Tank 2: _____ <input type="checkbox"/> Pumped Tank 3: _____ <input type="checkbox"/> Pumped Tank 4: _____ <input type="checkbox"/> Pumped Total Gallons Pumped: <u>1200</u>

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

***Tank Measurements-Use Only If Tank(s) Were NOT Pumped**

Tank Length _____ in. <input checked="" type="checkbox"/>	Tank Width _____ in. <input checked="" type="checkbox"/>	Tank Depth _____ in. =	Tank Volume (cubic inches) _____
Tank Radius _____ in. <input checked="" type="checkbox"/>	Tank Radius _____ in. <input checked="" type="checkbox"/>	3.14 =	Tank Volume (cubic inches) _____
Tank Volume (cu. in.) _____	/ 231.01 =	Liquid Capacity _____	Gallons / Tank Depth _____ in. = Gallons/Inch _____
Sludge Level _____ in. <input checked="" type="checkbox"/>	Gallons Per Inch _____ =	Sludge Volume _____	Gallons
Scum Level _____ in. <input checked="" type="checkbox"/>	Gallons Per Inch _____ =	Scum Volume _____	Gallons
Sludge Volume _____	+ Scum Volume _____ =	Total Sludge and Scum Volume _____	Gallons
Total Sludge and Scum Volume _____	/ Liquid Capacity _____ =	Percent Sludge and Scum in Tank _____	%



Tank Depth measured from invert of outlet pipe to bottom of tank

*Tanks must be pumped if either of the following conditions exist:
 1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
 2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.