

SSTS MAINTENANCE REPORT

System Location		
Address	705 Settlers Ridge	Telephone Number
City	Woodbury	Property ID No./GEO Code
State	MN ZIP 55	
Owner	Carol Demulling	Pumping Date
		10/19/05
Contractor		
Maintainer	MEYER SEWER	MPCA License No.
		915
		Telephone Number
		651-457-0162

What was done to the system?

Tank(s) Pumped

Sludge and scum measured.

Do tanks need to be pumped?

Yes No (If no provide measurements below)

Report Liquid Capacity in Gallons

Tank 1: 1500 Pumped Tank 2: Pumped

Tank 3: Pumped Tank 4: Pumped

Total Gallons Pumped: _____

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspector

***Tank Measurements-Use Only if Tank(s) Were NOT Pumped**

Tank Length _____ in. X Tank Width _____ in. X Tank Depth _____ in. = Tank Volume (cubic inches)

Tank Radius _____ in. X Tank Radius _____ in. X 3.14 = Tank Volume (cubic inches)


Tank Volume (cu. in.) _____ / 231.01 = Liquid Capacity _____ Gallons / Tank Depth _____ in. = Gallons/Inch

Sludge Level _____ in. X Gallons Per Inch _____ = Sludge Volume _____ Gallons

Scum Level _____ in. X Gallons Per Inch _____ = Scum Volume _____ Gallons

Sludge Volume _____ + Scum Volume _____ = Total Sludge and Scum Volume _____ Gallons

Total Sludge and Scum Volume _____ / Liquid Capacity _____ = Percent Sludge and Scum in Tank _____ %



Tank Depth measured from invert of outlet pipe to bottom of tank

Tanks must be pumped if either of the following conditions exist:

1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.