

SSTS MAINTENANCE REPORT

System Location			
Address	1770 St. Croix Trail S	Telephone Number	
City	St. Croix Beach	State	MN ZIP 55043
Owner	BUZZCO	Property ID No./GEO Code	
	Pumping Date	10/7/15	
Contractor			
Maintainer	MEYER SEWER	MPCA License No.	915
		Telephone Number	651-459-016


What was done to the system?
<input checked="" type="checkbox"/> Tank(s) Pumped / <input type="checkbox"/> Sludge and scum measured. Do tanks need to be pumped? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements below)

Report Liquid Capacity in Gallons
Tank 1: 500 <input checked="" type="checkbox"/> Pumped Tank 2: _____ <input type="checkbox"/> Pumped Tank 3: _____ <input type="checkbox"/> Pumped Tank 4: _____ <input type="checkbox"/> Pumped Total Gallons Pumped: 500

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

*Tank Measurements-Use Only If Tank(s) Were NOT Pumped			
Tank Length _____ in.	<input checked="" type="checkbox"/>	Tank Width _____ in.	<input checked="" type="checkbox"/>
Tank Depth _____ in.		= Tank Volume (cubic inches) _____	
Tank Radius _____ in.	<input checked="" type="checkbox"/>	Tank Radius _____ in.	<input checked="" type="checkbox"/>
		3.14 = Tank Volume (cubic inches) _____	
Tank Volume (cu. in.) _____	/ 231.01 =	Liquid Capacity _____ Gallons/	Tank Depth _____ in. = Gallons/Inch _____
Sludge Level _____ in.	<input checked="" type="checkbox"/>	Gallons Per Inch _____	= Sludge Volume _____ Gallons
Scum Level _____ in.	<input checked="" type="checkbox"/>	Gallons Per Inch _____	= Scum Volume _____ Gallons
Sludge Volume _____	+	Scum Volume _____	= Total Sludge and Scum Volume _____ Gallons
Total Sludge and Scum Volume _____	/	Liquid Capacity _____	= Percent Sludge and Scum in Tank _____ %



Scum Layer

Effluent

Sludge Layer

Tank Depth measured from invert of outlet pipe to bottom of tank

*Tanks must be pumped if either of the following conditions exist:
 1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
 2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Signature [Signature] Date 10/7/15 Reset Form