

SSTS MAINTENANCE REPORT

RECEIVED

JUL 31 2019

System Location			
Address	23190 lofton ave	Telephone Number	651-433-31
City	Scandia	State	mn ZIP 55073 Property ID No./GEO Code
Owner	al ahmann	Pumping Date	07/26/2019
Contractor			
Maintainer	Row Sewer Service	MPCA License No.	L3309 Telephone Number 6514655505

PUBLIC HEALTH

What was done to the system?

Tank(s) Pumped
 Sludge and scum measured.
 Do tanks need to be pumped?
 Yes No (If no provide measurements below)

Report Liquid Capacity in Gallons

Tank 1: 1000 Pumped Tank 2: 1000 Pumped
 Tank 3: _____ Pumped Tank 4: _____ Pumped
 Total Gallons Pumped: 2000

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

***Tank Measurements-Use Only If Tank(s) Were NOT Pumped**

Tank Length _____ in. Tank Width _____ in. Tank Depth _____ in. = Tank Volume (cubic inches) _____

Tank Radius _____ in. Tank Radius _____ in. **3.14** = Tank Volume (cubic inches) _____

Tank Volume (cu. in.) _____ / **231.01** = Liquid Capacity _____ Gallons / Tank Depth _____ in. = Gallons/Inch _____

Sludge Level _____ in. Gallons Per Inch _____ = Sludge Volume _____ Gallons

Scum Level _____ in. Gallons Per Inch _____ = Scum Volume _____ Gallons

Sludge Volume _____ + Scum Volume _____ = Total Sludge and Scum Volume _____ Gallons

Total Sludge and Scum Volume _____ / Liquid Capacity _____ = Percent Sludge and Scum in Tank _____ %

Scum Layer

Effluent

Sludge Layer

Tank Depth measured from invert of outlet pipe to bottom of tank

*Tanks must be pumped if either of the following conditions exist:
 1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
 2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Signature _____

Date 07/26/2019

Reset Form

Rowe Sewer/Wild River Contracting
Po Box 236
Taylors Falls, MN 55084

Midwest One Bank
St Croix Falls, WI 54024

No. 2635

75-511/919

Date 7/29/2019

Pay To The Order Of Washington County Dept of Public Health

\$ **22.00

Twenty-Two and 00/100

Dollars

Washington County Dept of Public Health
PO BOX 6
14949 62nd Street N
Stillwater, MN 55082

Memo:

Lisa Gerd

Rowe Sewer/Wild River Contracting
Washington County Dept of Public Health

2635

Date	Type	Reference	Original Amt.	Balance Due	7/29/2019 Discount	Payment
7/29/2019	Bill	ahmann	22.00	22.00		22.00
					Check Amount	22.00

Rowe Sewer Service

22.00