



DEPARTMENT OF PUBLIC HEALTH & SAFETY  
 14949 62nd STREET NORTH  
 Office: 651-430-6655 FAX: 651-430-6246

**Subsurface Sewage Treatment System**

This section must be completed in its entirety to constitute a valid maintenance permit prior to performing maintenance activities and remain on-site for the duration of this permit.

Date of Maintenance: 8-7-19 Reason for Maintenance: PM  
 Property Address: 28345 Keats Ave North Property Owner's Name: SEALED & CAPED  
 Municipality: Forest Lake ZIP: 55025 Property Identification Number: SEALED & CAPED  
 Maintenance Permit No: 10884d16369 Maintainer Name and License No. Olson's Sewer Service/L216

<input checked="" type="checkbox"/> Tanks(s) Pumped <input type="checkbox"/> Sludge and scum measured Do tanks need to be pumped? <input type="checkbox"/> Yes <input type="checkbox"/> No (if no provide measurements)	Liquid Level in Tank _____ Sludge Level in Tank _____ Sludge + Scum _____ % Sludge & Scum _____ Scum Level in Tank _____ Liquid Level _____ Tanks must be pumped if 25% or more
--	---

- Access used to remove septage:  Maintenance Hole  Other (enter authorization code)
- Were all covers securely replaced?  Yes  No
- Is there evidence of tank leakage from a septic, holding, pretreatment or pump tank below the operating depth evidence of damaged, cracked, or structurally unsound maintenance hole covers?  Yes  No

Tank	Leaking Out	Leaking In	Cover Damage
Septic/Holding Tank #1	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Septic/Holding Tank #2	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Pretreatment Tank	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No
Pump Tank	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No	<input type="checkbox"/> Yes <input type="checkbox"/> No

4. How many gallons of septage were removed?  
 Tank #1 1350 gal Tank #2 \_\_\_\_\_ gal Pretreatment tank \_\_\_\_\_ gal Pump Tank \_\_\_\_\_ gal

5. Other information: List any troubleshooting, minor repairs conducted, tank safety concerns, or other concerns.  
 \_\_\_\_\_

6. Location of septage disposal: St Paul, metro

Olson's Sewer Service Inc  
 17638 Lyons St NE  
 Forest Lake, MN 55025  
 License# 216 P: 651-464-2082