

**SSTS MAINTENANCE REPORT**

|                                 |                                  |                                      |
|---------------------------------|----------------------------------|--------------------------------------|
| <b>System Location</b>          |                                  |                                      |
| Address <u>10121 103rd St N</u> | Telephone Number                 |                                      |
| City <u>Stillwater</u>          | State <u>MN</u> ZIP <u>55082</u> | Property ID No./GEO Code             |
| Owner <u>Andrew Berwald</u>     | Pumping Date <u>8/28/15</u>      |                                      |
| <b>Contractor</b>               |                                  |                                      |
| Maintainer <u>MEYER SEWER</u>   | MPCA License No. <u>915</u>      | Telephone Number <u>651-459-0163</u> |

**What was done to the system?**

Tank(s) Pumped

Sludge and scum measured.  
Do tanks need to be pumped?  
 Yes  No (If no provide measurements below)

**Report Liquid Capacity in Gallons**

Tank 1: 1500  Pumped    Tank 2: 1000  Pumped

Tank 3: \_\_\_\_\_  Pumped    Tank 4: \_\_\_\_\_  Pumped

Total Gallons Pumped: 2500

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

**\*Tank Measurements-Use Only If Tank(s) Were NOT Pumped**

Tank Length \_\_\_\_\_ in.  Tank Width \_\_\_\_\_ in.  Tank Depth \_\_\_\_\_ in. = Tank Volume (cubic inches) \_\_\_\_\_

Tank Radius \_\_\_\_\_ in.  Tank Radius \_\_\_\_\_ in.  3.14 = Tank Volume (cubic inches) \_\_\_\_\_


Tank Volume (cu. in.) \_\_\_\_\_ / 231.01 = Liquid Capacity \_\_\_\_\_ Gallons / Tank Depth \_\_\_\_\_ in. = Gallons/Inch \_\_\_\_\_

Sludge Level \_\_\_\_\_ in.  Gallons Per Inch \_\_\_\_\_ = Sludge Volume \_\_\_\_\_ Gallons

Scum Level \_\_\_\_\_ in.  Gallons Per Inch \_\_\_\_\_ = Scum Volume \_\_\_\_\_ Gallons

Sludge Volume \_\_\_\_\_ + Scum Volume \_\_\_\_\_ = Total Sludge and Scum Volume \_\_\_\_\_ Gallons

Total Sludge and Scum Volume \_\_\_\_\_ / Liquid Capacity \_\_\_\_\_ = Percent Sludge and Scum in Tank \_\_\_\_\_ %



Tank Depth measured from invert of outlet pipe to bottom of tank

\*Tanks must be pumped if either of the following conditions exist:  
1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or  
2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Signature \_\_\_\_\_

Date \_\_\_\_\_

Reset Form