

OUTENIAMENT CENTERS

14949 62nd STREET NORTH P.O. BOX 6 STILLWATER, MN 55082-0006 Office: 651-430-6655 TDD: 651-430-6246 FAX: 651-430-6730

SSTS MAINTENANCE REPORT

System Location	
Address 499 Quinnell AUE.	Name of the Telephone Number
City Lalceland Stat	teMN ZIP55043 Property ID No./GEO Code
	mping Date 9/17/15
Contractor	
Maintainer MEYER SEWER MPC	TA License No. 915 Telephone Number 651-459-016
What was done to the system?	Report Liquid Capacity in Gallons
Tank(s) Pumped /	Tank 1: 1000 Pumped Tank 2: Pumped
Sludge and scum measured.	Tank 3: Pumped Tank 4: Pumped
Do tanks need to be pumped? Tes No (If no provide measurements below)	Total Gallons Pumped: 1000
Visual Inspection (note any problems with the system): NOTE: This does not serve as a compliance inspection.	
*Tank Measurements-Use Only If Tank(s) Were NOT Pumped	
Tank Length in. X Tank Width in.	X Tank Depth in. = Tank Volume (cubic inches)
Tank Radius in. X Tank Radius in.	X 3.14 = Tank Volume (cubic inches)
Tank Volume (cu. in.) / 231.01 = Liquid (Capacity Gallons / Tank Depth in. = Gallons / Inch
Sludge Level in. X Gallons Per Inch =	= Sludge Volume Gallons
	Scum Volume Gallons
Scum Level in. X Gallons Per Inch =	
Sludge Volume + Scum Volume =	= Total Sludge and Scum Volume Gallons
Total Sludge and Scum Volume / Liquid C	Capacity = Percent Sludge and Scum in Tank %
	*Tanks must be pumped if either of the following conditions exist: 1. The top of the sludge layer is less than
Scum Layer T	12 inches from the bottom of the outlet
Effluent	Tank Depth measured baffle; or 2, Total sludge and scum volume is greate
	than 25 percent of the tank's liquid
Sludge Layer	capacity.
Signature /	Date 9/17/15 Reset Form