

SSTS MAINTENANCE REPORT

System Location			
Address 8466 235th st n	Telephone Number	6513073841	
City Forest Lake	State mn ZIP 55025	Property ID No./GEO Code	
Owner Robert Trapp	Pumping Date 10/11/17		
Contractor			
Maintainer Row Sewer Service	MPCA License No. L3309	Telephone Number	6514655505

What was done to the system?
<input checked="" type="checkbox"/> Tank(s) Pumped
<input type="checkbox"/> Sludge and scum measured.
Do tanks need to be pumped?
<input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements below)

Report Liquid Capacity in Gallons			
Tank 1: 1200	<input checked="" type="checkbox"/> Pumped	Tank 2: _____	<input type="checkbox"/> Pumped
Tank 3: _____	<input type="checkbox"/> Pumped	Tank 4: _____	<input type="checkbox"/> Pumped
Total Gallons Pumped: <u>1200</u>			

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

RECEIVED
 SEP 30 2019
 PUBLIC HEALTH

*Tank Measurements-Use Only If Tank(s) Were NOT Pumped			
Tank Length _____ in.	<input checked="" type="checkbox"/> Tank Width _____ in.	<input checked="" type="checkbox"/> Tank Depth _____ in.	= Tank Volume (cubic inches) _____
Tank Radius _____ in.	<input checked="" type="checkbox"/> Tank Radius _____ in.	<input checked="" type="checkbox"/> 3.14	= Tank Volume (cubic inches) _____
Tank Volume (cu. in.) _____	/ 231.01 = Liquid Capacity _____	Gallons / Tank Depth _____ in.	= Gallons/Inch _____
Sludge Level _____ in.	<input checked="" type="checkbox"/> Gallons Per Inch _____	= Sludge Volume _____	Gallons
Scum Level _____ in.	<input checked="" type="checkbox"/> Gallons Per Inch _____	= Scum Volume _____	Gallons
Sludge Volume _____	+ Scum Volume _____	= Total Sludge and Scum Volume _____	Gallons
Total Sludge and Scum Volume _____	/ Liquid Capacity _____	= Percent Sludge and Scum in Tank _____	%

*Tanks must be pumped if either of the following conditions exist:

- The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
- Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Tank Depth measured from invert of outlet pipe to bottom of tank _____

Signature [Signature]

Date 10/11/20197

Reset Form