

SSTS MAINTENANCE REPORT

Date of Maintenance 10/10/19 Reason for Maintenance Routine
 Property Address: 12810 Oakhill Rd. Property Owner's Name: Joan Heller
 Municipality: Scanlon State _____ Zip Code 55073 GEO Code/Property I.D. #: _____

| | |
|--|---|
| <p>What was done to the system?</p> <p><input checked="" type="checkbox"/> Tank(s) Pumped</p> <p><input type="checkbox"/> Sludge and scum measured.</p> <p>Do tanks need to be pumped?</p> <p><input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements)</p> | <p>Tank Measurements (must be completed if tanks NOT pumped)</p> <p>Liquid Level of Tank _____ in. Sludge Level _____ in. Scum Level _____ in.</p> <p>Total (Sludge + Scum) _____ / Liquid Level _____ = % Sludge & Scum _____ *</p> |
|--|---|

1. Access used to remove septage: Maintenance Hole Other (Go to #3 below) * Tank must be pumped if this value is greater than 25%.
2. If maintenance hole was used, were all covers securely replaced? Yes No *please explain*

Explanation: _____

3. If owner refuses to allow a Subsurface Sewage Treatment System (SSTS) to be pumped through the maintenance hole, have them complete and sign the following statement:

I, _____ (owner's name), refuse to allow the removal of solids and liquids through the maintenance hole. I understand that removal of solids and liquids through other access points is not considered maintenance.

4. Is the tank designed as a leaky tank? example: seepage pit, cesspool, drywell, leaching pit

Tank#1 Yes No Verification Method Used: Visual

Tank#2 Yes No Verification Method Used: _____

5. Is there evidence of tank leakage from a septic, holding, pretreatment or pump tank below the operating depth or evidence of damaged, cracked, or structurally unsound maintenance hole covers?

| Tank | Leaking Out | Leaking In | Cover Damage |
|------------------------|---|---|---|
| Septic/Holding Tank #1 | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |
| Septic/Holding Tank #2 | <input type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Pretreatment Tank | <input type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |
| Pump Tank | <input type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No | <input type="checkbox"/> Yes <input type="checkbox"/> No |

6. How many gallons of septage were removed? 900

Tank #1 1000 Tank #2 _____ Pretreatment Tank _____ Pump Tank _____

7. Other information: List any troubleshooting, minor repairs conducted, tank safety concerns, or other concerns.

8. Certification: I hereby certify as a State of Minnesota certified SSTS Maintainer that I personally conducted the work and made the observations, or directly supervised others in the performance of this job.

Maintainer's Name: OSSI Maintainer's Address: 17638 Lyons St. NE
 Maintainer's License #: 216 Maintainer's Phone #: 464-2082
 Maintainer's Signature: John B. Date: 10/10/19