

## SSTS MAINTENANCE REPORT

| System Location |                     |                  |                                       |
|-----------------|---------------------|------------------|---------------------------------------|
| Address         | 1045 Oakgreen Ave N | Telephone Number |                                       |
| City            | Stillwater          | State            | MN ZIP 55082 Property ID No./GEO Code |
| Owner           | Don Vance           | Pumping Date     | 11/23/15                              |
| Contractor      |                     |                  |                                       |
| Maintainer      | MEYER SEWER         | MPCA License No. | 915 Telephone Number 651-459-016      |

| What was done to the system?   |
|--|
| <input checked="" type="checkbox"/> Tank(s) Pumped<br><input type="checkbox"/> Sludge and scum measured.<br>Do tanks need to be pumped?<br><input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements below) |

| Report Liquid Capacity in Gallons   |
|---|
| Tank 1: 1500 <input checked="" type="checkbox"/> Pumped Tank 2: 1500 <input checked="" type="checkbox"/> Pumped<br>Tank 3: 600 <input checked="" type="checkbox"/> Pumped Tank 4: _____ <input type="checkbox"/> Pumped<br>Total Gallons Pumped: 3500 |

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection

**\*Tank Measurements-Use Only If Tank(s) Were NOT Pumped**

Tank Length \_\_\_\_\_ in.  Tank Width \_\_\_\_\_ in.  Tank Depth \_\_\_\_\_ in. = Tank Volume (cubic inches) \_\_\_\_\_

Tank Radius \_\_\_\_\_ in.  Tank Radius \_\_\_\_\_ in.  3.14 = Tank Volume (cubic inches) \_\_\_\_\_


Tank Volume (cu. in.) \_\_\_\_\_ / 231.01 = Liquid Capacity \_\_\_\_\_ Gallons / Tank Depth \_\_\_\_\_ in. = Gallons/Inch \_\_\_\_\_

Sludge Level \_\_\_\_\_ in.  Gallons Per Inch \_\_\_\_\_ = Sludge Volume \_\_\_\_\_ Gallons

Scum Level \_\_\_\_\_ in.  Gallons Per Inch \_\_\_\_\_ = Scum Volume \_\_\_\_\_ Gallons

Sludge Volume \_\_\_\_\_ + Scum Volume \_\_\_\_\_ = Total Sludge and Scum Volume \_\_\_\_\_ Gallons

Total Sludge and Scum Volume \_\_\_\_\_ / Liquid Capacity \_\_\_\_\_ = Percent Sludge and Scum in Tank \_\_\_\_\_ %



Tank Depth measured from invert of outlet pipe to bottom of tank

\*Tanks must be pumped if either of the following conditions exist:  
 1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or  
 2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.