

SSTS MAINTENANCE REPORT

System Location		
Address <u>8404 Jamaica Ave N.</u>	Telephone Number <u>651-426-7583</u>	
City <u>Stillwater</u>	State <u>MN</u> ZIP <u>55082</u>	Property ID No./GEO Code <u>21.030.21.41.0002</u>
Owner <u>Steve + Penny Feely</u>	Pumping Date	
Contractor		
Maintainer	MPCA License No.	Telephone Number

What was done to the system?

Tank(s) Pumped

Sludge and scum measured. Do tanks need to be pumped?

Yes No (If no provide measurements below)

Report Liquid Capacity in Gallons

Tank 1: _____ Pumped Tank 2: _____ Pumped

Tank 3: _____ Pumped Tank 4: _____ Pumped

Total Gallons Pumped: _____


Visual Inspection (note any problems with the system): **NOTE: This does not serve as a compliance inspection.**

***Tank Measurements-Use Only if Tank(s) Were NOT Pumped**

Liquid Level of Tank (Distance from invert of outlet pipe to bottom of tank): 49 in.

Sludge Level 6.5 in. + Scum Level 2.5 in. = Total Sludge and Scum Level 9 in.

Total Sludge and Scum Level 9 in. / Liquid Level 49 in. = Sludge and Scum percent in Tank 18.4 %



*Tanks must be pumped if either of the following conditions exist:

1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Signature Steve Feely

Date: 10-29-19

2019
\$22.00 Processing Fee
 Make Checks payable and remit to:
 Washington County Public Health and Environment
 14949 62nd St
 Stillwater, MN 55082

RECEIVED
OCT 31 2019
PUBLIC HEALTH