

## SSTS MAINTENANCE REPORT

| System Location                    |                                  |   |
|------------------------------------|----------------------------------|---|
| Address <u>7560 Harkness Ave S</u> | Telephone Number _____           |   |
| City <u>Cottage Grove</u>          | State <u>MN</u> ZIP <u>55016</u> | Property ID No./GEO Code <u>08.027.21.32.0014</u> |
| Owner <u>Matt Edman</u>            | Pumping Date <u>10/2/15</u>      |   |
| Contractor                         |                                  |   |
| Maintainer <u>MEYER SEWER</u>      | MPCA License No. <u>915</u>      | Telephone Number <u>651-459-016</u>               |

| What was done to the system?   |
|--|
| <input checked="" type="checkbox"/> Tank(s) Pumped<br><input type="checkbox"/> Sludge and scum measured.<br>Do tanks need to be pumped?<br><input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements below) |

| Report Liquid Capacity in Gallons   |
|---|
| Tank 1: <u>1500</u> <input checked="" type="checkbox"/> Pumped    Tank 2: <u>1000</u> <input checked="" type="checkbox"/> Pumped<br>Tank 3: _____ <input type="checkbox"/> Pumped    Tank 4: _____ <input type="checkbox"/> Pumped<br>Total Gallons Pumped: <u>2500</u> |

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

### RECEIVED

JAN 06 2016

### PUBLIC HEALTH

**\*Tank Measurements-Use Only If Tank(s) Were NOT Pumped**

Tank Length \_\_\_\_\_ in.  Tank Width \_\_\_\_\_ in.  Tank Depth \_\_\_\_\_ in. = Tank Volume (cubic inches) \_\_\_\_\_

Tank Radius \_\_\_\_\_ in.  Tank Radius \_\_\_\_\_ in.  **3.14** = Tank Volume (cubic inches) \_\_\_\_\_


Tank Volume (cu. in.) \_\_\_\_\_ / **231.01** = Liquid Capacity \_\_\_\_\_ Gallons / Tank Depth \_\_\_\_\_ in. = Gallons/Inch \_\_\_\_\_

Sludge Level \_\_\_\_\_ in.  Gallons Per Inch \_\_\_\_\_ = Sludge Volume \_\_\_\_\_ Gallons

Scum Level \_\_\_\_\_ in.  Gallons Per Inch \_\_\_\_\_ = Scum Volume \_\_\_\_\_ Gallons

Sludge Volume \_\_\_\_\_ + Scum Volume \_\_\_\_\_ = Total Sludge and Scum Volume \_\_\_\_\_ Gallons

Total Sludge and Scum Volume \_\_\_\_\_ / Liquid Capacity \_\_\_\_\_ = Percent Sludge and Scum in Tank \_\_\_\_\_ %



Tank Depth measured from invert of outlet pipe to bottom of tank

\*Tanks must be pumped if either of the following conditions exist:  
 1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or  
 2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Signature \_\_\_\_\_

Date \_\_\_\_\_

Reset Form