


SSTS MAINTENANCE REPORT



System Location	
Address <u>8935 Lake Janz Trail N</u>	Telephone Number
City <u>Lake Elmo</u>	State <u>MN</u> ZIP <u>55042</u> Property ID No./GEO Code <u>09029.21.41</u>
Owner <u>Greg Gelbmann</u>	Pumping Date <u>10/1/15</u> <u>0005</u>
Contractor	
Maintainer <u>MEYER SEWER</u>	MPCA License No. <u>915</u> Telephone Number <u>651-459-016</u>

What was done to the system?

Tank(s) Pumped 2

Sludge and scum measured.

Do tanks need to be pumped?

Yes No (If no provide measurements below)

Report Liquid Capacity in Gallons

Tank 1: 750 Pumped Tank 2: 750 Pumped

Tank 3: Pumped Tank 4: Pumped

Total Gallons Pumped: 1500

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

RECEIVED
JAN 06 2016
PUBLIC HEALTH

***Tank Measurements-Use Only if Tank(s) Were NOT Pumped**

Tank Length in. Tank Width in. Tank Depth in. = Tank Volume (cubic inches)

Tank Radius in. Tank Radius in. **3.14** = Tank Volume (cubic inches)

Tank Volume (cu. in.) / **231.01** = Liquid Capacity Gallons / Tank Depth in. = Gallons/Inch

Sludge Level in. Gallons Per Inch = Sludge Volume Gallons

Scum Level in. Gallons Per Inch = Scum Volume Gallons

Sludge Volume + Scum Volume = Total Sludge and Scum Volume Gallons

Total Sludge and Scum Volume / Liquid Capacity = Percent Sludge and Scum in Tank %

Scum Layer

Effluent

Sludge Layer

*Tanks must be pumped if either of the following conditions exist:

1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Tank Depth measured from invert of outlet pipe to bottom of tank

Signature [Signature] Date 10/1/15 Reset Form