

SSTS MAINTENANCE REPORT

System Location		
Address	4410 McDonald DR. Ct. N.	Telephone Number
City	Stillwater	State MN ZIP 55082 Property ID No./GEO Code
Owner	Jim Russow	Pumping Date 10/22/15
Contractor		
Maintainer	MEYER SEWER	MPCA License No. 915 Telephone Number 651-459-016

What was done to the system?
<input checked="" type="checkbox"/> Tank(s) Pumped 2 <input type="checkbox"/> Sludge and scum measured. Do tanks need to be pumped? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements below)


Report Liquid Capacity in Gallons
Tank 1: 1000 <input checked="" type="checkbox"/> Pumped Tank 2: 1000 <input checked="" type="checkbox"/> Pumped Tank 3: _____ <input type="checkbox"/> Pumped Tank 4: _____ <input type="checkbox"/> Pumped Total Gallons Pumped: 2000

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

***Tank Measurements-Use Only If Tank(s) Were NOT Pumped**

Tank Length _____ in.	<input checked="" type="checkbox"/>	Tank Width _____ in.	<input checked="" type="checkbox"/>	Tank Depth _____ in.	=	Tank Volume (cubic inches) _____
Tank Radius _____ in.	<input checked="" type="checkbox"/>	Tank Radius _____ in.	<input checked="" type="checkbox"/>	3.14	=	Tank Volume (cubic inches) _____
Tank Volume (cu. in.) _____	/	231.01	=	Liquid Capacity _____	Gallons /	Tank Depth _____ in. = Gallons/Inch _____
Sludge Level _____ in.	<input checked="" type="checkbox"/>	Gallons Per Inch _____	=	Sludge Volume _____	Gallons	
Scum Level _____ in.	<input checked="" type="checkbox"/>	Gallons Per Inch _____	=	Scum Volume _____	Gallons	
Sludge Volume _____	+	Scum Volume _____	=	Total Sludge and Scum Volume _____	Gallons	
Total Sludge and Scum Volume _____	/	Liquid Capacity _____	=	Percent Sludge and Scum in Tank _____	%	



Tank Depth measured from invert of outlet pipe to bottom of tank

- *Tanks must be pumped if either of the following conditions exist:
1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
 2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Signature

Date 10/22/15