

## SSTS MAINTENANCE REPORT

System Location		
Address	1544 Remacha Ave S	Telephone Number
City	St Croix Beach	State MN ZIP 55043
Owner	Tom McCarthy	Property ID No./GEO Code
	Pumping Date 12/18/15	
Contractor		
Maintainer	MEYER SEWER	MPCA License No. 915
		Telephone Number 651-459-0162

**What was done to the system?**

Tank(s) Pumped

Sludge and scum measured.

Do tanks need to be pumped?

Yes  No (If no provide measurements below)

**Report Liquid Capacity in Gallons**

Tank 1: 1200  Pumped Tank 2:  Pumped

Tank 3:  Pumped Tank 4:  Pumped

Total Gallons Pumped: 1200

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspector

**\*Tank Measurements-Use Only if Tank(s) Were NOT Pumped**

Tank Length: \_\_\_\_\_ in.  Tank Width: \_\_\_\_\_ in.  Tank Depth: \_\_\_\_\_ in. = Tank Volume (cubic inches)

Tank Radius: \_\_\_\_\_ in.  Tank Radius: \_\_\_\_\_ in.  3.14 = Tank Volume (cubic inches)


Tank Volume (cu. in.) / 231.01 = Liquid Capacity \_\_\_\_\_ Gallons / Tank Depth \_\_\_\_\_ in. = Gallons/inch

Sludge Level \_\_\_\_\_ in.  Gallons Per Inch \_\_\_\_\_ = Sludge Volume \_\_\_\_\_ Gallons

Scum Level \_\_\_\_\_ in.  Gallons Per Inch \_\_\_\_\_ = Scum Volume \_\_\_\_\_ Gallons

Sludge Volume \_\_\_\_\_ + Scum Volume \_\_\_\_\_ = Total Sludge and Scum Volume \_\_\_\_\_ Gallons

Total Sludge and Scum Volume \_\_\_\_\_ / Liquid Capacity \_\_\_\_\_ = Percent Sludge and Scum in Tank \_\_\_\_\_ %



Tank Depth measured from invert of outlet pipe to bottom of tank

Tanks must be pumped if either of the following conditions exist:

1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.