

SSTS MAINTENANCE REPORT

System Location		
Address <u>8200 Jamaica Ave. N</u>	Telephone Number _____	
City <u>Stillwater</u>	State <u>MN</u> ZIP <u>55082</u>	Property ID No./GEO Code _____
Owner <u>Cynthia Hammel</u>	Pumping Date <u>12/10/15</u>	
Contractor		
Maintainer <u>MEYER SEWER</u>	MPCA License No. <u>915</u>	Telephone Number <u>651-459-016</u>

What was done to the system?
<input checked="" type="checkbox"/> Tank(s) Pumped / <input type="checkbox"/> Sludge and scum measured. Do tanks need to be pumped? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements below)

Report Liquid Capacity in Gallons			
Tank 1: <u>1250</u> <input checked="" type="checkbox"/> Pumped	Tank 2: _____	<input type="checkbox"/> Pumped	
Tank 3: _____	<input type="checkbox"/> Pumped	Tank 4: _____	<input type="checkbox"/> Pumped
Total Gallons Pumped: <u>1250</u>			

Visual Inspection (note any problems with the system): _____

NOTE: This does not serve as a compliance inspection

***Tank Measurements-Use Only if Tank(s) Were NOT Pumped**

Tank Length _____ in. X Tank Width _____ in. X Tank Depth _____ in. = Tank Volume (cubic inches) _____

Tank Radius _____ in. X Tank Radius _____ in. X 3.14 = Tank Volume (cubic inches) _____


Tank Volume (cu. in.) _____ / 231.01 = Liquid Capacity _____ Gallons / Tank Depth _____ in. = Gallons/Inch _____

Sludge Level _____ in. X Gallons Per Inch _____ = Sludge Volume _____ Gallons

Scum Level _____ in. X Gallons Per Inch _____ = Scum Volume _____ Gallons

Sludge Volume _____ + Scum Volume _____ = Total Sludge and Scum Volume _____ Gallons

Total Sludge and Scum Volume _____ / Liquid Capacity _____ = Percent Sludge and Scum in Tank _____ %



Tanks must be pumped if either of the following conditions exist:

1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Tank Depth measured from invert of outlet pipe to bottom of tank _____