



SSTS MAINTENANCE REPORT

Address <u>13460 182nd St</u>		Telephone Number <u>651-433-3218</u>	
City <u>MARINE</u>	State <u>MN</u>	ZIP <u>55047</u>	Property ID No./GEO Code
Owner <u>Arnold & Carol Dahlstrom</u>		Pumping Date <u>2-7-16</u>	
Maintainer <u>Olson Sewer</u>	MPCA License No. <u>216</u>	Telephone Number <u>651-464-2082</u>	

Tank(s) Pumped
 Sludge and scum measured.
 Do tanks need to be pumped?
 Yes No (If no provide measurements below)

Report Results Summary in Tables

Tank 1: <u>931</u>	<input checked="" type="checkbox"/> Pumped	Tank 2: _____	<input type="checkbox"/> Pumped
Tank 3: _____	<input type="checkbox"/> Pumped	Tank 4: _____	<input type="checkbox"/> Pumped
Total Gallons Pumped: <u>931</u>			

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

Tank Length _____ in.	<input checked="" type="checkbox"/> Tank Width _____ in.	<input checked="" type="checkbox"/> Tank Depth _____ in.	= Tank Volume (cubic inches) _____
Tank Radius _____ in.	<input checked="" type="checkbox"/> Tank Radius _____ in.	<input checked="" type="checkbox"/> 3.14	= Tank Volume (cubic inches) _____
Tank Volume (cu. in.) _____	/ 231.01 = Liquid Capacity _____	Gallons / Tank Depth _____ in.	= Gallons/Inch _____
Sludge Level _____ in.	<input checked="" type="checkbox"/> Gallons Per Inch _____	= Sludge Volume _____	Gallons
Scum Level _____ in.	<input checked="" type="checkbox"/> Gallons Per Inch _____	= Scum Volume _____	Gallons
Sludge Volume _____	+ Scum Volume _____	= Total Sludge and Scum Volume _____	Gallons
Total Sludge and Scum Volume _____	/ Liquid Capacity _____	= Percent Sludge and Scum in Tank _____	%

*Tanks must be pumped if either of the following conditions exist:
 1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
 2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Tank Depth measured from invert of outlet pipe to bottom of tank _____

Signature [Handwritten Signature]

Date 2-7-16

