

SSTS MAINTENANCE REPORT

System Location		
Address <u>16460 20th St S</u>	Telephone Number	
City <u>St Croix Beach</u>	State <u>MN</u> ZIP <u>55043</u>	Property ID No./GEO Code
Owner <u>Allen Lund</u>	Pumping Date <u>10/20/15</u>	
Contractor		
Maintainer <u>MEYER SEWER</u>	MPCA License No. <u>915</u>	Telephone Number <u>651-459-016</u>

What was done to the system?
<input checked="" type="checkbox"/> Tank(s) Pumped <input type="checkbox"/> Sludge and scum measured. Do tanks need to be pumped? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements below)


Report Liquid Capacity in Gallons
Tank 1: <u>1500</u> <input checked="" type="checkbox"/> Pumped Tank 2: _____ <input type="checkbox"/> Pumped Tank 3: _____ <input type="checkbox"/> Pumped Tank 4: _____ <input type="checkbox"/> Pumped Total Gallons Pumped: <u>1500</u>

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

*Tank Measurements-Use Only if Tank(s) Were NOT Pumped

Tank Length _____ in.	<input checked="" type="checkbox"/>	Tank Width _____ in.	<input checked="" type="checkbox"/>	Tank Depth _____ in.	= Tank Volume (cubic inches) _____
Tank Radius _____ in.	<input checked="" type="checkbox"/>	Tank Radius _____ in.	<input checked="" type="checkbox"/>	3.14	= Tank Volume (cubic inches) _____
Tank Volume (cu. in.) _____	/	231.01	= Liquid Capacity _____	Gallons / Tank Depth _____ in.	= Gallons/Inch _____
Sludge Level _____ in.	<input checked="" type="checkbox"/>	Gallons Per Inch _____	= Sludge Volume _____	Gallons	
Scum Level _____ in.	<input checked="" type="checkbox"/>	Gallons Per Inch _____	= Scum Volume _____	Gallons	
Sludge Volume _____	+	Scum Volume _____	= Total Sludge and Scum Volume _____	Gallons	
Total Sludge and Scum Volume _____	/	Liquid Capacity _____	= Percent Sludge and Scum in Tank _____	%	



Tank Depth measured from invert of outlet pipe to bottom of tank

*Tanks must be pumped if either of the following conditions exist:
 1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
 2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.