

SSTS MAINTENANCE REPORT

System Location	
Address <u>5367 Jamaca Ave. W</u>	Telephone Number
City <u>Lake Elmo</u>	State <u>MN</u> ZIP <u>55042</u> Property ID No./GEO Code
Owner <u>Richard Dessel</u>	Pumping Date <u>11/16/15</u>
Contractor	
Maintainer <u>MEYER SEWER</u>	MPCA License No. <u>915</u> Telephone Number <u>651-459-016</u>

What was done to the system?
<input checked="" type="checkbox"/> Tank(s) Pumped / <input type="checkbox"/> Sludge and scum measured. Do tanks need to be pumped? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements below)

Report Liquid Capacity in Gallons	
Tank 1: <u>1500</u> <input checked="" type="checkbox"/> Pumped	Tank 2: _____ <input type="checkbox"/> Pumped
Tank 3: _____ <input type="checkbox"/> Pumped	Tank 4: _____ <input type="checkbox"/> Pumped
Total Gallons Pumped: <u>1500</u>	

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspector

***Tank Measurements-Use Only If Tank(s) Were NOT Pumped**

Tank Length _____ in. Tank Width _____ in. Tank Depth _____ in. = Tank Volume (cubic inches) _____

Tank Radius _____ in. Tank Radius _____ in. **3.14** = Tank Volume (cubic inches) _____


Tank Volume (cu. in.) _____ / **231.01** = Liquid Capacity _____ Gallons / Tank Depth _____ in. = Gallons/Inch _____

Sludge Level _____ in. Gallons Per Inch _____ = Sludge Volume _____ Gallons

Scum Level _____ in. Gallons Per Inch _____ = Scum Volume _____ Gallons

Sludge Volume _____ + Scum Volume _____ = Total Sludge and Scum Volume _____ Gallons

Total Sludge and Scum Volume _____ / Liquid Capacity _____ = Percent Sludge and Scum in Tank _____ %



Tank Depth measured from invert of outlet pipe to bottom of tank

*Tanks must be pumped if either of the following conditions exist:
 1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
 2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

[Handwritten signature] 11/16/15