

SSTS MAINTENANCE REPORT



System Location		
Address	11591 Mckusick Road N	Telephone Number
City	Stillwater	State MN ZIP 55082 Property ID No./GEO Code
Owner	Ryan McManimon	Pumping Date 9/17/15
Contractor		
Maintainer	MEYER SEWER	MPCA License No. 915 Telephone Number 651-459-016

What was done to the system?
<input checked="" type="checkbox"/> Tank(s) Pumped <input type="checkbox"/> Sludge and scum measured. Do tanks need to be pumped? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements below)

Report Liquid Capacity in Gallons			
Tank 1:	1200	<input checked="" type="checkbox"/> Pumped	Tank 2: <input type="checkbox"/> Pumped
Tank 3:		<input type="checkbox"/> Pumped	Tank 4: <input type="checkbox"/> Pumped
Total Gallons Pumped:		1200	

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

*Tank Measurements-Use Only If Tank(s) Were NOT Pumped			
Tank Length	in. X	Tank Width	in. X Tank Depth in. = Tank Volume (cubic inches)
Tank Radius	in. X	Tank Radius	in. X 3.14 = Tank Volume (cubic inches)
Tank Volume (cu. in.)	/ 231.01 =	Liquid Capacity	Gallons/ Tank Depth in. = Gallons/Inch
Sludge Level	in. X	Gallons Per Inch	= Sludge Volume Gallons
Scum Level	in. X	Gallons Per Inch	= Scum Volume Gallons
Sludge Volume	+	Scum Volume	= Total Sludge and Scum Volume Gallons
Total Sludge and Scum Volume	/	Liquid Capacity	= Percent Sludge and Scum in Tank %

*Tanks must be pumped if either of the following conditions exist:

1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Tank Depth measured from invert of outlet pipe to bottom of tank

Signature

Date 9/17/15

Reset Form