

SSTS MAINTENANCE REPORT

System Location			
Address	40 Evergreen Road	Telephone Number	
City	White Bear Lake	State	MN ZIP 55110
Owner	Scott St. Martin	Pumping Date	9/22/15
Contractor			
Maintainer	MEYER SEWER	MPCA License No.	915
		Telephone Number	651-459-016

What was done to the system?
<input checked="" type="checkbox"/> Tank(s) Pumped 2 <input type="checkbox"/> Sludge and scum measured. Do tanks need to be pumped? <input type="checkbox"/> Yes <input type="checkbox"/> No (If no provide measurements below)


Report Liquid Capacity in Gallons
Tank 1: 1250 <input checked="" type="checkbox"/> Pumped Tank 2: 1250 <input checked="" type="checkbox"/> Pumped Tank 3: _____ <input type="checkbox"/> Pumped Tank 4: _____ <input type="checkbox"/> Pumped Total Gallons Pumped: 2500

Visual Inspection (note any problems with the system):

NOTE: This does not serve as a compliance inspection.

***Tank Measurements-Use Only If Tank(s) Were NOT Pumped**

Tank Length _____ in.	<input checked="" type="checkbox"/>	Tank Width _____ in.	<input checked="" type="checkbox"/>	Tank Depth _____ in.	= Tank Volume (cubic inches) _____
Tank Radius _____ in.	<input checked="" type="checkbox"/>	Tank Radius _____ in.	<input checked="" type="checkbox"/>	3.14 =	Tank Volume (cubic inches) _____
Tank Volume (cu. in.) _____	/	231.01 =	Liquid Capacity _____	Gallons /	Tank Depth _____ in. = Gallons/Inch _____
Sludge Level _____ in.	<input checked="" type="checkbox"/>	Gallons Per Inch _____	=	Sludge Volume _____	Gallons
Scum Level _____ in.	<input checked="" type="checkbox"/>	Gallons Per Inch _____	=	Scum Volume _____	Gallons
Sludge Volume _____	+	Scum Volume _____	=	Total Sludge and Scum Volume _____	Gallons
Total Sludge and Scum Volume _____	/	Liquid Capacity _____	=	Percent Sludge and Scum in Tank _____	%



Tank Depth measured from invert of outlet pipe to bottom of tank

*Tanks must be pumped if either of the following conditions exist:
 1. The top of the sludge layer is less than 12 inches from the bottom of the outlet baffle; or
 2. Total sludge and scum volume is greater than 25 percent of the tank's liquid capacity.

Signature *Alt*

Date 9/22/15

Reset Form