



**Department of Public Health and Environment**  
 14949 62nd Street North PO Box 6  
 Stillwater MN 55082-0006  
 Office: 651-430-6655 TTY: 651-430-6246 Fax: 651-430-6730

Review Fee:	\$205.00
Permit Fee:	\$215.00
<b>Total Fee:</b>	<b>\$420.00</b>
Previous Payment	\$420.00
Balance Due	\$0.00

Community: Denmark Township  
 Permit Number: 0004-04-016  
 Owner: Mittelstaedt Brothers Const  
 2530 151st CT W  
 Rosemount MN 55068-  
 Applicant: Mittelstaedt Brothers Const

*Scanned 8/11/08 BM*

0004-04-016

**PERMISSION IS HEREBY GRANTED**

To execute the work specified in this permit on the following identified property upon express condition that said persons and their agents, and employees shall conform in all respects to the provisions of Ordinance #128, Washington County Development Code, Chapter Four, Individual Sewage Treatment System Regulations. This permit may be revoked at any time upon violation of any of the provisions of said ordinance.

Project Address: 11751 120th ST S  
 Geo Code: 01-026-21-11-0004  
 Designer: Benson Septic Service

Type of System: Standard Drainfield		Pressure Distribution	
Design Criteria		Drainfield Sizing	
Percolation Rate:	25	Square Feet:	1200
Depth To Restriction:	58	Lineal:	400 Feet
Land Slope:	2.00%	Depth Of Rock Below:	12 Inches
Flow Rate:	600	Maximum Trench Depth:	16 Inches
Number of Bedrooms:	4	Number Of Trenches:	5
<input type="checkbox"/> Gravelless		Length Of Trenches:	80 Feet
<input type="checkbox"/> Chambered		Spacing Of Trenches:	7.5 Feet
Tank Sizes			
Tank 1:	1000	Tank 2:	1000
Tank 3:	0	Lift Station:	0

**Authorized Work/Special Conditions**

1. Back-up area for second future on-site system must be protected from all traffic.
2. Install individual sewage treatment system as per approved design in area tested and shown on the site plan.
3. Maximum trench depth 12-24 inches into natural soil
4. Please check with the post office to verify the city and zip code in the 'Project Address' listed above.
5. This system must be installed by a certified/licensed sewage treatment system installer holding a current license with the Minnesota Pollution Control Agency. (A list of installers is available at your request.)

Permit Issue Date: 6/7/2004  
 Permit Expiration Date: 6/7/2005

Christopher W. LeClair, REHS  
 Senior Environmental Specialist