



MUNICIPAL BUILDING
 2100 Radio • Woodbury, Minnesota 55125
 Building Inspection 731-5770



PRIVATE SEWAGE SYSTEM
 PERMIT

Please Print

1. Building Site Address 6800 Glen Road
 2. Contractor Rumpca Sewer & WATER Phone 469-1556
 3. Contractor Address 700 Pullman Ave City St. Paul Park
 4. Owner Greg McElroy Phone _____

5. Minimum systems requirements
 Number Bedrooms 3
 Percolation Rate 15 MPI
 Septic tank size 2-1000 Gal.
 Absorption trenches
 Number Lines 206 Linear Feet
 Width 36"
 Depth 36"
 Rock below Tile 12"
 Rock above Tile 2"
 Spacing of Trenches 7-6"

6. Permit Fee 50.00
 Plancheck Fee _____
 Other Fee _____
 Surcharge 50
 TOTAL FEE 50.50

Other Perc Report & Septic design by Mike Schneider #546

i. Signature _____ Date _____

System must be inspected and approved before covering any portion of the system.

Permit No. _____ Permit Date _____ Receipt No. _____

Legal Description: Lot _____ Block _____ Addition _____ Area _____

Comments Replacement Porcelain System. A plumbing permit will be required when pay changes inside the dwelling occur.

Approved By Wm Rumpca 10-25-70 White Building file
 From 2610 Disk 21 Canary Office copy
 Pink Contractor