

WASHINGTON COUNTY, MINNESOTA

Sewage Treatment Permit No. 200(6F227)

Inspection of Installation Must Be Made By the Building Official Before Any Portion of System is Covered
Contact Planning Department, 779-5444, 24 Hour Notice Required

Owner GORDON W. EDGEPAHL
Property Description Lot 13 Rearrangement of Pine Tree Estates Sec 6 T30N R21W E3660 - 200
Property Address 10455 Hadley Circle N., White Bear Lake
Use of Building: SINGLE FAMILY RES. Flow Rate: 3 Bedrooms Percolation Rate: 15 mpi
Septic Tank 1200 Gal. Liquid Capacity Lift Station (if needed) 1000 Gal.
Type of System: SEPTIC TANK AND DRAINFIELD WITH LIFT STATION
Absorption Trench — Square Feet 458 Lineal Feet 153 Width 3 FT
Depth of Rock Below Lines 18 inches, Above Lines 2 inches
Depth of Trench From Existing Grade — Minimum 26 inches, Maximum 42 inches
Recommended Number of Lines 3 @ 51 FT (Note: Maximum Length of Individual Line is 100 Feet.)
Minimum Spacing of Lines 7 1/2 Ft. Center to Center
Special Conditions Install system in area tested and shown on site plan.

PERMIT: Permission is hereby granted to the above named applicant to perform the work described in the applicaiton to the minimum specifications shown above and per attached site plan. This permit is granted upon express condition that the person to whom it is granted, and his agents, employees and workmen shall conform in all respects to ordinances of Washington County, Minnesota. This permit may be revoked at any time upon violation of any said ordinance, and permit shall be void if work is not commenced within six (6) months.

INSTALLER MUST HOLD CURRENT SEPTIC/INSTALLER LICENSE WITH WASHINGTON COUNTY.

Approved: [Signature] Date 9/13/86
Zoning Administrator/Authorized Agent

Comments SYSTEM SUBSTANTIALLY COMPLETE 11/24/86

Installation Approved [Signature] Date 5/29/87
Inspector

Distribution: White—Applicant Canary—File Pink—Inspector Goldenrod—Municipality