

12/13/2021

Arcola Mills Historic Foundation  
12909 Arcola Trail N  
Stillwater, MN 55082

RE: Compliance Inspection Report at 12909 Arcola Trail N

The Washington County Department of Public Health and Environment (Department) administers Subsurface Sewage Treatment System (SSTS) regulations in Washington County.

A compliance report regarding an inspection of the existing system at 12909 Arcola Trail North was received and accepted. The report identifies the facility is served by a 3,000-gallon holding tank system without soil treatment area capacity. If the property is considering expansion of use or additional wastewater capacity, please note Washington County Ordinance #206, Section 6.2 requires a permit for change in use of a facility served by a subsurface sewage treatment system.

Lastly, the inspection report noted the following at the time of inspection, 1) the alarm system was not functioning, and 2) infiltration into the tank at the risers was observed. It is important to address known leaks immediately as a holding tank can only store a limited amount of wastewater. It is also important to ensure the alarm is functioning properly as it is intended to notify the owner when the tank is near capacity to minimize chance of accidental overflow.

Please contact me if you have any questions regarding this information.

Respectfully,

A handwritten signature in black ink that reads "Sarah Borrell".

Sarah Borrell  
Sr. Environmental Specialist



*A great place to live, work and play...today and tomorrow*

Government Center • 14949 62nd Street North • P.O. Box 6 • Stillwater, MN 55082-0006  
Telephone: 651-430-6655 • Fax: 651-430-6730 • TTY: 651-430-6246  
[www.co.washington.mn.us](http://www.co.washington.mn.us)

*Washington County is an equal opportunity organization and employer*