



Department of Public Health and Environment
 14949 62nd Street North PO Box 6
 Stillwater MN 55082-0006
 Office: 651-430-6655 TTY: 651-430-6246 Fax: 651-430-6730

Review Fee:	\$285.00
Permit Fee:	\$480.00
Total Fee:	\$765.00
Previous Payment	\$765.00
Balance Due	\$0.00

PAID 5-15-12

Community: Grant
 Permit Number: 2700-12-2
 Owner: Jeff Disch
 7837 Jamaca AVE N
 Stillwater MN 55082-
 Applicant: Bill Wolfe Excavating

PERMISSION IS HEREBY GRANTED

To execute the work specified in this permit on the following identified property upon express condition that said persons and their agents and employees shall conform in all respects to the provisions of Ordinance #179, Washington County Development Code, Chapter Four, Subsurface Sewage Treatment System Regulations. This permit may be revoked at any time upon violation of any of the provisions of said ordinance.

Project Address: 7837 Jamaca AVE N
 Geo Code: 27-030-21-22-0001
 Designer: Inspect Minnesota, Midwest Soil Testing

2700-12-2

Type of System: Mound		Pressure Distribution	
Design Criteria		Mound Sizing	
Percolation Rate:	6	Rock Bed Width:	10 Feet
Depth To Restriction:	22	Rock Bed Length:	45 Feet
Land Slope:	4.00%	Absorption Width:	15 Feet
Flow Rate:	450	Depth of Clean Sand:	14 Inches
Number of Bedrooms:	3	Downslope Dike Width:	18 Feet
		Upslope Dike:	11 Feet
		Length of Dike:	74 Feet
Tank Sizes		Number Of Laterals:	
Tank 1: 1000	Tank 2: 1000	Tank 3: 0	Lift Station: 1000
		Perforation Spacing:	
		Perforation Diameter:	
		Head Size:	
		Total Head:	
		Connection:	
		Length of Laterals:	
		Perforations / Lateral:	
		Total Perforations:	
		Gallons Per Minute:	
		Lateral Diameter:	

Authorized Work/Special Conditions

1. Effluent Filter with Alarm Required
2. Pressure laterals must have cleanouts to grade.

Permit Issue Date: 5/15/2012
 Permit Expiration Date: 5/15/2013

P. Ganzel
 Pete Ganzel
 Senior Environmental Specialist