

LLOYD CHALUPSKY

PARCEL D
132ND ST. NO.
14460

SCALE: 1" = APPROX. 60' IN
HOUSE + BORING LAYOUT
+ FRONT FOOTAGE

HIGH
KNOLL
WATER
AREA
P.
B44
B45
B5-604
B5-605
LOCATE THE WELL
50' FROM THE
FUTURE AREA
LOW AREA - FILL
TO GET GRAVITY
TO THE DRAINFIELD
APPROX.
HOUSE
LOCATION
WELL
DRIVE
AWAY
WET
LAND
TWO 1000 GALL. SEPTIC
TANKS - 24" MANHOLES
+ 4" CLEAN DRAWS
TO GRADE

1200 SQ. FT. DRAINFIELD
7 RUNS - 60' LONG
36" WIDE - 24" TO 30" DEEP
7'6" CENTER TO CENTER
TRENCH SPACING
FOLLOW THE CONTOURS
KEEP BOTTOM OF TRENCH
LEVEL

BORING FOR
INSPECTION

4" INS.
PIPES
KNOWN
B43
B44
B45
P2
E41
4" CLEAN
DRAWS ON
BOXES
ELEVATION
LINE
153.53

24"
TO
30"
FILLED FABRIC
2" OF ROCK OVER THE PIPE
12" OF ROCK BELOW THE PIPE
36"

DRAINFIELD CROSS SECTION
NO SCALE

No.
13 St.

134