

Compliance inspection report form

520 Lafayette Road North St. Paul, MN 55155-4194 **Existing Subsurface Sewage Treatment System (SSTS)**

Doc Type: Compliance and Enforcement

Instructions: Inspection results based on Minnesota Pollution Control Agency (MPCA) requirements and attached supporting documentation – additional local requirements may also apply. Further information can be found here: https://www.pca.state.mn.us/sites/default/files/wq-wwists4-31a.pdf.

Inspector must submit completed form to Local Governmental Unit (LGU) and system owner within 15 days of final determination of compliance or noncompliance.

Property information	Local tracking number:		
cel ID# or Sec/Twp/Range: 1102820420082			
Property address: 1533 QUENTIN AVE S, CITY OF LAKE ST CROIX BEACH			
Owner/representative: HEGGERNESS CHERYL A	Owner's phone:		
Brief system description: 1250-GALLON SEPTIC TANK AND GRAV	/ITY DRAINFIELD		
System status			
System status on date (mm/dd/yyyy): 6/8/2021			
☐ Compliant – Certificate of compliance*	Noncompliant - Notice of noncompliance		
(Valid for 3 years from report date unless evidence of an imminent threat to public health or safety requiring removal and abatement under section 145A.04, subdivision 8 is discovered or a shorter time frame exists in Local Ordinance.) *Note: Compliance indicates conformance with Minn.	An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance or under section 145A.04 subdivision 8. Systems failing to protect ground water must be upgraded, replaced, or use discontinued within the time required by local		
R. 7080.1500 as of system status date above and does not guarantee future performance.	ordinance.		
Soil separation (Compliance component #5) – Failing to	protect groundwater #3) – Imminent threat to public health and safety #3) – Failing to protect groundwater O (Compliance component #3) – Failing to protect groundwater		
I hereby certify that all the necessary information has been gathered determination of future system performance has been nor can be ma abuse of the system, inadequate maintenance, or future water usage	de due to unknown conditions during system construction, possible		
By typing my name below, I certify the above statements to be true can be used for the purpose of prosessing this form,	and correct, to the best of my knowledge, and that this information		
Business name: LASHINSKI SERVICES, INC.	Certification number: 3053		
Inspector signature:	License number: L65		
(This document has been electronically signed)	Phone: 612-919-3704		
Necessary or locally required supporting docur			
Soil observation logs	☐ Operating Permit		
Other information (list):	Za rank integrity Assessment		
☐ Other information (list).			

https://www.pca.state.mn.us wq-wwists4-31b • 1/11/21 651-296-6300

800-657-3864

Use your preferred relay service

Available in alternative formats

1. I

Compliance criteria:		Attached supporting documentation:	
System discharges sewage to the ☐ Yes* ☒ No		Other:	
ground surface		☐ Not applicable	
System discharges sewage to drain tile or surface waters.	☐ Yes* ☒ No		
System causes sewage backup into dwelling or establishment.	⊠ Yes* □ No		
Any "yes" answer above indicates imminent threat to public health an	_		
Describe verification methods and	results:		
ank integrity – Compliance	component #2	of 5	
ank integrity – Compliance Co mpliance criteria:	component #2		
Compliance criteria:	component #2	Attached supporting documentation:	
<u> </u>	•		LASHINSI SEPTIC
Compliance criteria: System consists of a seepage pit, cesspool, drywell, leaching pit,	•	Attached supporting documentation: ☐ Pumped at time of inspection	LASHINSI SEPTIC

If yes, which sewage tank(s) leaks: Any "yes" answer above indicates the system is failing to protect groundwater.

Describe verification methods and results:

ROOTS GROWING IN TANK

Attached supporting documentation:		
□ Pumped at time of inspection		
Name of maintenance b	usiness:	LASHINSKI SEPTIC
License number of maintenance business: L65		: <u>L65</u>
Date of maintenance:		6/8/2021
☐ Existing tank integrity assessment (Attach)		
Date of maintenance (mm/dd/yyyy):	(must be within t	three years)
(See form instructions to ensure assessment complies with Minn. R. 7082.0700 subp. 4 B (1))		
☐ Tank is Noncompliant (pumping not necessary – explain below)		
☐ Other:		

800-657-3864

3.	Other compliance conditions – Compliance component #3 of 5	
	3a. Maintenance hole covers appear to be structurally unsound (damaged, cracked, etc.), or unsec ☐ Yes* ☒ No ☐ Unknown	cured?
	3b. Other issues (electrical hazards, etc.) to immediately and adversely impact public health or safety *Yes to 3a or 3b - System is an imminent threat to public health and safety.	? ☐ Yes* ☒ No ☐ Unknown
	3c. System is non-protective of ground water for other conditions as determined by inspector?	☐ Yes* ☒ No
	3d. System not abandoned in accordance with Minn. R. 7080.2500?	☐ Yes*
	*Yes to 3c or 3d - System is failing to protect groundwater.	
	Describe verification methods and results:	
	Attached supporting documentation: Not applicable	
4.	Operating permit and nitrogen BMP* – Compliance component #4 of	5 Not applicable
	Is the system operated under an Operating Permit? ☐ Yes ☒ No If	f "yes", A below is required
	Is the system required to employ a Nitrogen BMP specified in the system design? ☐ Yes ☒ No If	f "yes", B below is required
	BMP = Best Management Practice(s) specified in the system design	
	If the answer to both questions is "no", this section does not need to be completed	
	Compliance criteria:	
	a. Have the operating permit requirements been met?	
	·	
	b. Is the required nitrogen BMP in place and properly functioning? Yes No	
	Any "no" answer indicates noncompliance.	
	Describe verification methods and results:	
	Attached supporting documentation: Operating permit (Attach)	

https://www.pca.state.mn.us wq-wwists4-31b • 1/11/21

5. Soil separation – Compliance component #5 of 5

Date of installation (mm/dd/yyyy)	_⊠ Unknown		
Shoreland/Wellhead protection/Food beverage lodging? Compliance criteria (select one): 5a. For systems built prior to April 1, 1996, and not located in Shoreland or Wellhead Protection Area or not serving a food, beverage or lodging establishment: Drainfield has at least a two-foot vertical separation distance from periodically saturated soil or bedrock.	Yes □ No Yes □ No*	Attached supporting documentation: ☐ Soil observation logs completed for the ☐ Two previous verifications of required separation (Attach) ☐ Not applicable (No soil treatment area ☐	vertical
5b. Non-performance systems built April 1, 1996, or later or for non-performance systems located in Shoreland or Wellhead Protection Areas or serving a food, beverage, or lodging establishment: Drainfield has a three-foot vertical separation distance from periodically saturated soil or bedrock.*	☐ Yes ☒ No*	Indicate depths or elevations A. Bottom of distribution media B. Periodically saturated soil/bedrock C. System separation D. Required compliance separation* *May be reduced up to 15 percent if allo Ordinance.	30" Wet at 58" 28" 36" wed by Local
5c. "Experimental", "Other", or "Performance" systems built under pre-2008 Rules; Type IV or V systems built under 2008 Rules 7080. 2350 or 7080.2400 (Advanced Inspector License required) Drainfield meets the designed vertical separation distance from periodically saturated soil or bedrock. *Any "no" answer above indicates the			

Describe verification methods and results:

failing to protect groundwater.

Upgrade requirements: (Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.



Compliance Inspection Attachment for Existing Individual Sewage Treatment Systems

Address 1533 Quentin Avenue	
------------------------------------	--

Boring #1 Elevation:	Boring #2 Elevation	Elevation:
0-12 10YR 4/4 sandy loam -28 10YR 5/4 gravelly sandy loam.		
-66 10YR 5/3, gravelly coarse sand. >35% rock fragments after 48". Soil wet after 56' w/ 10YR 6/2 depleted matrix		

Sketch

Benchmark = Top of drainfield. Assumed elevation = 100'0". The system consists of a 1250-gallon septic tank and gravity drainfield. Both the tank and distribution box are overloaded with the liquid level above normal levels. Roots are entering into the septic tank. The system is classified as noncompliant. Contact Washington County for upgrade requirements. This inspection is not a warranty or guarantee, either written or implied, of future or long-term hydraulic functionality/performance, but rather a determination if the systems use is/may cause pollution and/or adverse harm to the environment, groundwater or public health and safety at the time of this inspection. No quarantee can be made on future hydraulic performance, or the performance of system components. Changes in use can cause any system, failing or compliant, to become hydraulically overloaded and ultimately fail. Owner/buyer assumes full responsibility for the long-term performance of this system as well as any future upgrade, repairs or replacement costs. Liability is limited to the cost of this inspection.

Washington County, MN

