

## Compliance inspection report form

**Existing Subsurface Sewage Treatment System (SSTS)** 

520 Lafayette Road North St. Paul, MN 55155-4194

Doc Type: Compliance and Enforcement

**Instructions:** Inspection results based on Minnesota Pollution Control Agency (MPCA) requirements and attached supporting documentation – additional local requirements may also apply. Further information can be found here: https://www.pca.state.mn.us/sites/default/files/wq-wwists4-31a.pdf.

Inspector must submit completed form to Local Governmental Unit (LGU) and system owner within 15 days of final determination of compliance or noncompliance.

<b>Property information</b>		Local tracking number:				
Parcel ID# or Sec/Twp/Range:						
Property address: 19841 Jeffr	perty address: 19841 Jeffrey Circle N, Forest Lake MN 55025					
Owner/representative: Dan Ne	einstadt	Owner's ph	none: 651-271-2190			
Brief system description: 1500	rief system description: 1500 combo main 1000 main and 1000 lift to a pressure bed system					
System status						
System status on date (mm/dd/	/yyyy): <u>7/9/2021</u>					
	of compliance*	☐ Noncompliant – Notice of noncom	ıpliance			
an imminent threat to pub removal and abatement u subdivision 8 is discovere	eport date unless evidence of lic health or safety requiring under section 145A.04, and or a shorter time frame exists	An imminent threat to public health a upgraded, replaced, or its use discor receipt of this notice or within a short local ordinance or under section 145	ntinued within ten months of ter period if required by			
	cates conformance with Minn. em status date above and ire performance.	Systems failing to protect ground wa replaced, or use discontinued within ordinance.				
Reason(s) for noncon	npliance (check all applicable	<del>2</del> )				
☐ Tank integrity (Com ☐ Other Compliance ( ☐ Other Compliance ( ☐ System not abando ☐ Soil separation (Con	pliance component #2) – Failing to Conditions (Compliance componen Conditions (Compliance componen ned according to Minn. R. 7080.25 mpliance component #5) – Failing onitoring plan requirements (Component #5)	at #3) – Imminent threat to public health a at #3) – Failing to protect groundwater 600 (Compliance component #3) – Failing	and safety g to protect groundwater			
Certification						
determination of future system pabuse of the system, inadequate	performance has been nor can be n e maintenance, or future water usa	_	ystem construction, possible			
can be used for the purpose of p	· · · · · · · · · · · · · · · · · · ·	ue and correct, to the best of my knowled	ge, and that this information			
Business name: MJL Contracting Inc.		Certification number: 8190				
Inspector signature: Danielle Lang		License number: 2449				
(This document has been electronically signed)		Phone: <u>763-244-9070</u>				
Necessary or locally re	equired supporting doc	umentation (must be attached)				
<ul><li>☑ Soil observation logs</li><li>☐ Other information (list):</li></ul>		☐ Tank Integrity Assessment	☐ Operating Permit			

## 1. Impact on public health – Compliance component #1 of 5 Compliance criteria: Attached supporting documentation: ☐ Yes\* ⊠ No Other: System discharges sewage to the ground surface ☐ Not applicable ☐ Yes\* ☐ No System discharges sewage to drain tile or surface waters. ☐ Yes\* ☒ No System causes sewage backup into dwelling or establishment. Any "yes" answer above indicates the system is an imminent threat to public health and safety. Describe verification methods and results: searched for seepage in yard 2. Tank integrity - Compliance component #2 of 5 Compliance criteria: Attached supporting documentation: System consists of a seepage pit, ☐ Yes\* ☐ No Pumped at time of inspection cesspool, drywell, leaching pit, or other pit? Name of maintenance business: Hassle Free Sewage tank(s) leak below their ☐ Yes\* ☐ No License number of maintenance business: 3287 designed operating depth? 7/9/2021 Date of maintenance: ☐ Existing tank integrity assessment (Attach)

Describe verification methods and results:

Any "yes" answer above indicates the system

If yes, which sewage tank(s) leaks:

is failing to protect groundwater.

Visual

Date of maintenance (mm/dd/yyyy):

Other:

Minn. R. 7082.0700 subp. 4 B (1))

(must be within three years)

(See form instructions to ensure assessment complies with

☐ Tank is Noncompliant (pumping not necessary – explain below)

3.	Other compliance conditions – Compliance component #3 of 5				
3a. Maintenance hole covers appear to be structurally unsound (damaged, cracked, etc.), or unsecured?  ☐ Yes* ☒ No ☐ Unknown					
	3b. Other issues (electrical hazards, etc.) to immediately and adversely impact public health or safety  *Yes to 3a or 3b - System is an imminent threat to public health and safety.	/? ☐ Yes*   ☑ No ☐ Unknown			
	3c. System is non-protective of ground water for other conditions as determined by inspector?	☐ Yes* ☒ No			
	3d. System not abandoned in accordance with Minn. R. 7080.2500?	☐ Yes* ☒ No			
	*Yes to 3c or 3d - System is failing to protect groundwater.				
	Describe verification methods and results:				
	Visual				
	Attached supporting documentation: ⊠ Not applicable □				
4.	Operating permit and nitrogen BMP* – Compliance component #4 or	f 5 🛭 Not applicable			
	Is the system operated under an Operating Permit?	f "yes", A below is required			
	Is the system required to employ a Nitrogen BMP specified in the system design?   Yes  No I	f "yes", B below is required			
	BMP = Best Management Practice(s) specified in the system design				
	If the answer to both questions is "no", this section does not need to be completed				
	Compliance criteria:				
	a. Have the operating permit requirements been met? ☐ Yes ☐ No				
	b. Is the required nitrogen BMP in place and properly functioning?  Yes No				
	Any "no" answer indicates noncompliance.				
	Describe verification methods and results:				
	Describe vernication methods and results.				
	Attached supporting documentation:   Operating permit (Attach)				
	Attached supporting documentation:   Operating permit (Attach)				

https://www.pca.state.mn.us wq-wwists4-31b • 1/11/21

## 5. Soil separation – Compliance component #5 of 5

Date of installation 3/24/2014 (mm/dd/yyyy)	_		
Shoreland/Wellhead protection/Food beverage lodging?  Compliance criteria (select one):  5a. For systems built prior to April 1, 1996, and not located in Shoreland or Wellhead Protection Area or not serving a food, beverage or lodging establishment:  Drainfield has at least a two-foot vertical separation distance from periodically	Yes No	Attached supporting documentation:  ☐ Soil observation logs completed for the ☐ Two previous verifications of required separation (Attach)  ☐ Not applicable (No soil treatment area	vertical
saturated soil or bedrock.  5b. Non-performance systems built April 1, 1996, or later or for non-performance systems located in Shoreland or Wellhead Protection Areas or serving a food, beverage, or lodging establishment:  Drainfield has a three-foot vertical separation distance from periodically saturated soil or bedrock.*	⊠ Yes □ No*	Indicate depths or elevations  A. Bottom of distribution media  B. Periodically saturated soil/bedrock  C. System separation  D. Required compliance separation*  *May be reduced up to 15 percent if allo Ordinance.	20" 60" 40" 36" wed by Local
5c. "Experimental", "Other", or "Performance" systems built under pre-2008 Rules; Type IV or V systems built under 2008 Rules 7080. 2350 or 7080.2400 (Advanced Inspector License required)  Drainfield meets the designed vertical separation distance from periodically saturated soil or bedrock.  *Any "no" answer above indicates the			

Describe verification methods and results:

failing to protect groundwater.

**Upgrade requirements:** (Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.