

Lisa Faribault
Keller Williams Integrity
1350 Lagoon Ave S
Suite 900, Minneapolis, MN
55408

On August 5, 2021 the Washington County Department of Public Health and Environment (Department) received a Compliance Inspection Report from MJL Contracting Inc. indicating that the septic system located at 23677 St. Croix Trail, City of Scandia is failing to protect groundwater. The report indicates that the system does not have the required soil separation of 24 inches, as required for all septic systems installed before 1996. The report did not find the septic system to pose an imminent threat to public health or the environment.

Sincerely,

A handwritten signature in cursive script that reads "Tyler Dale".

Tyler Dale
Senior Environmental Specialist
651-430-6741



A great place to live, work and play...today and tomorrow

Government Center • 14949 62nd Street North • P.O. Box 6 • Stillwater, MN 55082-0006
Telephone: 651-430-6655 • Fax: 651-430-6730 • TTY: 651-430-6246
www.co.washington.mn.us

Washington County is an equal opportunity organization and employer