



Department of Public
Health and Environment

Lowell Johnson

Director

July 14, 2016

1302921340025

Robert Ambercrombie
3091 Layton Court N
Lake Elmo MN, 55042

On 6/17/2016 the Department received a Compliance Inspection for the subsurface sewage treatment system (SSTS) located at 3091 Layton Court N in Lake Elmo, Minnesota, GEO Code 1302921340025. The compliance inspection was conducted by Inspect Minnesota & Midwest Soil Testing on 6/13/2016.

The Compliance Inspection Report by Inspect Minnesota & Midwest Soil Testing indicates that the SSTS located at 3091 Layton Court N is a failing system due to the lack of the required vertical separation between the bottom system bottom and limiting soil conditions and the presence of a cesspool. The Compliance Inspection Report also indicates that the system is NOT an imminent threat to public health and safety.

Per an agreement between the City of Lake Elmo and the Department, since municipal sewer will be available to the property by 2016, the Department will not require the SSTS at 3091 Layton Court N to be replaced at this time.

If you have any questions or comments, please contact me at 651-430-4052.

Sincerely,

A handwritten signature in purple ink, appearing to read "C. LeClair".

Christopher W. LeClair, R.E.H.S.
Sr. Environmental Specialist
Washington County Department of
Public Health & Environment
651-430-4052
Chris.LeClair@co.washington.mn.us

Government Center • 14949 62nd Street North — P.O. Box 6, Stillwater, Minnesota 55082-0006
Phone: 651-430-6655 • Fax: 651-430-6730 • TTY: 651-430-6246
www.co.washington.mn.us
Equal Employment Opportunity / Affirmative Action

