

## 1. Impact on public health – Compliance component #1 of 5

### Compliance criteria:

System discharges sewage to the ground surface	<input type="checkbox"/> Yes* <input checked="" type="checkbox"/> No
System discharges sewage to drain tile or surface waters.	<input type="checkbox"/> Yes* <input checked="" type="checkbox"/> No
System causes sewage backup into dwelling or establishment.	<input type="checkbox"/> Yes* <input checked="" type="checkbox"/> No

*Any "yes" answer above indicates the system is an imminent threat to public health and safety.*

### Describe verification methods and results:

### Attached supporting documentation:

- Other: \_\_\_\_\_
- Not applicable

## 2. Tank integrity – Compliance component #2 of 5

### Compliance criteria:

System consists of a seepage pit, cesspool, drywell, leaching pit, or other pit?	<input type="checkbox"/> Yes* <input checked="" type="checkbox"/> No
Sewage tank(s) leak below their designed operating depth?	<input checked="" type="checkbox"/> Yes* <input type="checkbox"/> No
If yes, which sewage tank(s) leaks:	All three

*Any "yes" answer above indicates the system is failing to protect groundwater.*

### Describe verification methods and results:

Tanks not water tight. Two house tanks in bad shape. Wall caving in and rock and dirt pumped out. No one living in house now. Holding tank by barn not water tight.

### Attached supporting documentation:

- Pumped at time of inspection

Name of maintenance business: Schlomkas

License number of maintenance business: \_\_\_\_\_

Date of maintenance: 8/27/2021

- Existing tank integrity assessment (Attach)

Date of maintenance (mm/dd/yyyy): \_\_\_\_\_ (must be within three years)

*(See form instructions to ensure assessment complies with Minn. R. 7082.0700 subp. 4 B (1))*

- Tank is Noncompliant (pumping not necessary – explain below)

- Other: \_\_\_\_\_