| 5 | of | 1 | 0 |
|---|----|---|---|
| 0 | o. |   | • |

| Property Address: | Washington County      |
|-------------------|------------------------|
| Business Name     | Midwest Sewer Services |

Date: 2/23/2022

## **5.** Soil separation – Compliance component #5 of 5

| Date of installation 2000/2014<br>(mm/dd/yyyy)   | Unkr  | iown  |   |                               |
|--|-------|-------|---|-------------------------------|
| Shoreland/Wellhead protection/Food<br>beverage lodging?Image YesCompliance criteria (select one):  |       | No No | Attached supporting documentation:  |                               |
| <ul> <li>5a. For systems built prior to April 1, 1996, and<br/>not located in Shoreland or Wellhead<br/>Protection Area or not serving a food,<br/>beverage or lodging establishment:</li> <li>Drainfield has at least a two-foot vertical<br/>separation distance from periodically<br/>saturated soil or bedrock.</li> </ul> |       | □ No* | <ul> <li>Not applicable (No soil treatment area</li> <li>Reviewed design and permit records.</li> </ul> | )                             |
| 5b. Non-performance systems built<br>April 1, 1996, or later or for non-<br>performance systems located in Shoreland<br>or Wellhead Protection Areas or serving a<br>food, beverage, or lodging establishment:<br>Drainfield has a three-foot vertical<br>separation distance from periodically<br>saturated soil or bedrock.* |       | □ No* | Indicate depths or elevationsA. Bottom of distribution media  | See Attached<br>Boring Log(s) |
|  |       |       | B. Periodically saturated soil/bedrock<br>C. System separation  |                               |
|  |       |       | D. Required compliance separation*<br>*May be reduced up to 15 percent if allo                          | wed by Local                  |
|  | □ Yes | □ No* | Ordinance.  | wed by Local                  |
| systems built under pre-2008 Rules;<br>Type IV or V systems built under 2008<br>Rules 7080. 2350 or 7080.2400<br>(Intermediate Inspector License required ≤<br>2,500 gallons per day; Advanced Inspector<br>License required > 2,500 gallons per day)  |       |       | Upslope of mound has 13" of sand.   |                               |
| Drainfield meets the designed vertical separation distance from periodically saturated soil or bedrock.  |       |       |   |                               |

\*Any "no" answer above indicates the system is failing to protect groundwater.

Describe verification methods and results:

**Upgrade requirements:** (*Minn. Stat.* § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.