

Application Fee \$75.00

Permit Fee \$75.00

Additional Reviews \$25.00/hr. (1 hr. min.)

Reinspection Fee \$25.00/hr. (1 hr. min.)

Note: Subject To

APPLICATION FOR PERMIT TO INSTALL SEWAGE TREATMENT SYSTEM
WASHINGTON COUNTY PLANNING DEPARTMENT

Washington County Planning Dept.
14900 - 61st Street North
Stillwater, Minnesota 55082

Officials Approval

1	Legal Description and Parcel Number	PINEASANT RIDGE, PHASE 3 WESTLAKELAND TWP.			
2	Owner	Mail Address	City	Zip	Phone
	DAVID R. SCREATON	2474 OAK GREEN AVE. NO.	STILLWATER, MN.	55082	437-7860
3	Testor	Mail Address	City	Zip	Phone
	EARTH SCIENCE TESTING	20620 JUNO AVE. NO.	FOREST LAKE, MN.	55085	433-2890
4	Installer	Mail Address	City	Zip	Phone
5	Use of Building:	NEW HOME		Number of Bedrooms or Gallons Per Day	
	Is a Garbage Disposal to be connected to this System?	Yes	No		
6	Type of Work:	___ New	___ Alteration	___ Repair	<u>X</u> Approval Only
7	Has site previously been reviewed by Washington County? (If previously approved, attach letter of approval)	<u>X</u> No		___ Yes	___ Approved ___ Denied
<p>The following exhibits are required as a part of this application and shall be attached hereto: Percolation Tests Logs; Soil Boring Logs; Site Plan drawn to scale showing location of Buildings, Lot Lines, Percolation Test Holes, Soil Boring Holes, Proposed Location of System, and Well. Also, the house and the drainfield area must be staked. One copy of the final building plan must be available for review at the time application is processed. Improper or inadequate test or information will result in delays in processing.</p> <p>Agreement: The undersigned hereby makes Application for Permit to Install or Extend Sewage Treatment System herein specified, agreeing that all such work shall be done in strict accordance with ordinances and regulations of the County of Washington, Minnesota. Applicant agrees that the Site Plan, Sketches, and Specifications submitted herewith, and which are approved by the Washington County Zoning Administrator, together with any requirement and/or restriction made necessary by conditions peculiar to a particular location, shall become a part of the permit. Applicant further agrees to provide access, at reasonable times, to the Zoning Administrator or his agent for the purpose of performing inspections required and that no part of the system shall be covered until it has been inspected and accepted. Application is for an installation at a specific location on the site; any deviation from the approved location will cause the permit to become void. It shall be the responsibility of the applicant for the permit to notify the Office of the Zoning Administrator that the installation is ready for inspection.</p>					
		6 JAN 1989		DATE	
		for: David R. Scraton		by: H. Weaver	
				SIGNATURE OF APPLICANT	

FOR OFFICE USE ONLY

Reviews: Planner: _____

Inspector: _____

Date: 1/4/89

Site Evaluation:

Soil Boring Evaluation: Depth of Water Table, Seasonal Water Table (Mottled Soil), Impervious Layer or Bedrock: no limitations noted, 42 in min. prox. bench depth

Soils Map Data: _____

Percolation Test Evaluation: 32

Topography: 3% 4% slope SE

Pump System Required: Yes ___ No probably

Satbacks: _____

Required (circle)

Actual

Well (including adjacent property)	50'	75'			
Lake, Pond, Stream, River, or Bluffline	40'	75'	100'	150'	200'
Buildings (including adjacent property)	20'				
Property Lines	10'				

Conclusions:

Site Suitable:

Site Unsuitable:

Additional Tests Required:

Verify No. Bedrooms:

Notes:

Open area. Prof boxes required. Medium to coarse loamy sand soil.