



Client / Address:		16021 6TH ST N, CITY OF LAKELAND		Legal Description / GPS:		3502920320022	
Soil parent material(s): (Check all that apply)							
<input type="checkbox"/> Summit		<input type="checkbox"/> Shoulder		<input checked="" type="checkbox"/> Outwash		<input type="checkbox"/> Lacustrine	
<input type="checkbox"/> Alluvium		<input type="checkbox"/> Bedrock		<input type="checkbox"/> Organic Matter			
Landscape Position: (check one)							
<input type="checkbox"/> Toe Slope		<input type="checkbox"/> Foot Slope		<input checked="" type="checkbox"/> Back/Side Slope		<input type="checkbox"/> Linear / Linear	
Vegetation		Grass		Soil survey map units 7B		Slope %	
Weather Conditions / Time of Day:		40 degrees Cloudy		Date		04/04/22	
Observation # / Location:				See Map			
Depth (in)		Texture		Rock Frag. %		Matrix Color(s)	
0-20"		Sandy Loam		<35%		7.5YR 2.5/3	
21"- 60"		Sand		<35%		7.5YR 3/4	
Indicator(s)		Redox Kind(s)		Mottle Color(s)		Shape	
Granular		Granular		Granular		Weak	
Consistence		Grade		Structure		Auger	
Loose		Loose		Loose		Loose	
Comments							
I hereby certify that I have completed this work in accordance with all applicable ordinances, rules and laws.							
Shelley Schlomka		4137		4/4/2022			
(Designer/Inspector)		(License #)		(Date)			