Property Address: 4142 PENFIELD AVE S, CITY OF AFTON  Business Name: SS Septic Solutions, LLC Date: 5/24/2022						
5.	Soil separation	– Compliance cor	npone	nt #5 o	f 5	
9	Date of installation	ate of installation 7/29/2016 (mm/dd/yyyy)		iown		
	Shoreland/Wellhead protection/Food beverage lodging?		☐ Yes ⊠ No		Attached supporting documentation:  ☑ Soil observation logs completed for the report  ☐ Two previous verifications of required vertical separation	
9	Compliance criteria (select one):					
	5a. For systems built prior to April 1, 1996, and not located in Shoreland or Wellhead Protection Area or not serving a food, beverage or lodging establishment: Drainfield has at least a two-foot vertical separation distance from periodically saturated soil or bedrock.		☐ Yes	□No	☐ Not applicable (No soil treatment area)	
ţ	5b. Non-performance systems built April 1, 1996, or later or for non- performance systems located in Shoreland or Wellhead Protection Areas or serving a food, beverage, or lodging establishment:  Drainfield has a three-foot vertical separation distance from periodically saturated soil or bedrock.*  5c. "Experimental", "Other", or "Performance" systems built under pre-2008 Rules; Type IV or V systems built under 2008 Rules 7080. 2350 or 7080.2400 (Intermediate Inspector License required ≤ 2,500 gallons per day; Advanced Inspector License required > 2,500 gallons per day)  Drainfield meets the designed vertical separation distance from periodically saturated soil or bedrock.		⊠ Yes □ N	□ No	Indicate depths or elevations	T
					A. Bottom of distribution media	+24"
					B. Periodically saturated soil/bedrock	18"
					C. System separation	36"
					D. Required compliance separation*	36"
					*May be reduced up to 15 percent if allo Ordinance.	owed by Local
Ę			☐ Yes	□No		
	2016 1989 1988 4 2	methods and results:  NACEMENT SOILS  O. AII FILE	(Fill	15011	) OKAY by COUN re With WAShingt	ty

**Upgrade requirements:** (Minn. Stat. § 115.55) An imminent threat to public health and safety (ITPHS) must be upgraded, replaced, or its use discontinued within ten months of receipt of this notice or within a shorter period if required by local ordinance. If the system is failing to protect ground water, the system must be upgraded, replaced, or its use discontinued within the time required by local ordinance. If an existing system is not failing as defined in law, and has at least two feet of design soil separation, then the system need not be upgraded, repaired, replaced, or its use discontinued, notwithstanding any local ordinance that is more strict. This provision does not apply to systems in shoreland areas, Wellhead Protection Areas, or those used in connection with food, beverage, and lodging establishments as defined in law.